

PLANT 5 PRIME

Customer: PTRHTF10195

Baker Manufacturing, LLC. 1349 Rockland Rd. Lake Bluff, IL 60044 US Attn: Jeremy Huntington Tel: (847)514-9253

E-Mail: jhuntington@peterbaker.com

System Information

System Volume: 250 gal

Bulk Operating Temp: 330F / 166C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make: HYWAY BY GENCOR

Sample Information


Lab No: 02556041 Analyst: Yvette Trzcinski Sample Date: 05/01/23 Received Date: 05/08/23 Completed: 05/15/23 Yvette Trzcinski

yvette.trzcinski@HFSinclair.com

Recommendation: smaller system - having issues with deposit in filters. the high acid number and solid deposit plugging up the filters and issues keeping system hot recommend. Draining, flushing system and recharge with Petro-Therm

Comments: Calcium ppm levels are severely high. Visc @ 40°C is severely low. Acid Number (AN) is abnormally high. COC Flash Point is marginally low. (GCD) 90% Distillation Point is marginally low.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.