




INCINERATOR SYSTEM


Customer: PTRHTF10069	System Information	Sample Information
CERTAINTEED - SAINT GOBAIN 3303 EAST 4TH AVENUE SHAKOPEE, MN 55379 US Attn: Alex Hanley Tel: E-Mail: Alex.J.Hanley@saint-gobain.com	System Volume: 3000 gal Bulk Operating Temp: 550F / 288C Heating Source: Blanket: Fluid: PETRO CANADA CALFLO AF Make: JOHN ZINK	Lab No: 02562406 Analyst: Neil Buchanan Sample Date: 06/05/23 Received Date: 06/06/23 Completed: 06/08/23 Neil Buchanan neil.buchanan@HFSinclair.com

Recommendation: Sample looks good and no action required. Resample next interval.

Comments:




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
06/05/23	06/06/23	0.0y	FILTER BYPASS	439 / 226	9.2	30.5	0.19	0.083	699 / 371	798 / 425	898 / 481	2.18
04/19/22	05/10/22	0.0y		414 / 212	5.3	30.2	0.20	0.015	701 / 372	798 / 426	899 / 482	1.65
04/29/21	05/11/21	6.0y		432 / 222	14.3	28.9	0.15	0.069	694 / 368	785 / 419	897 / 480	2.31
06/18/20	06/29/20	0.0y	main system	406 / 208	14.9	30.4	0.20	0.108	703 / 373	799 / 426	897 / 481	1.64
09/24/19	10/21/19	0.0y	MAIN SYSTEM FLOW	401 / 205	21.0	30.2	0.145	0.242	705 / 374	786 / 419	873 / 467	0.46
Baseline Data				435 / 224		32.7	0.03		693 / 367	790 / 421	887 / 475	2.5





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
06/05/23	60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	65	0
04/19/22	56	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	64	0
04/29/21	61	0	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	66	0
06/18/20	41	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	78	0
09/24/19	7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	68	0
Baseline Data			0	0						0			0	0					0				270	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments

04/19/22	Sample looks good. Resample next interval to monitor.
04/29/21	Iron levels show a noticeable increase but the sample remains very dry and so not from rust. Sample looks good otherwise. Resample next interval to monitor.
06/18/20	Sample properties remain good and constant. An increase in Iron is noted on a dry system which can be from new parts installed. Resample next interval to monitor.
09/24/19	The oil is holding steady with the properties remaining normal. Contamination by asphalt, water or other elements is insignificant or non-detectable. No actions needed at this time. Re-sample at next scheduled interval

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.