




Recommendation: The fluid is in a reasonable condition and suitable for further use. The AN is elevated (0.59) but not to point where the fluid has become corrosive. The elevated AN in combination a decreased 10% GCD temperature and increased low boiler vapor content of 4.93% indicates normal (acceptable) thermal degradation of the fluid. It is recommended to vent off low boiler vapor. Please resample in 12 months. Since this is a large volume system consideration should be given to sweetening of the fill. This to limit acid number increase at an early stage instead of having to replace the whole volume when AN reaches the limit. (Acid Number increase progresses exponentially)

Comments: Acid Number (AN) is abnormally high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
06/01/23	06/15/23	16.0y		421 / 216	0.00	37.0	0.59	0.106	686 / 363	789 / 420	916 / 491	4.93
11/04/20	11/16/20	14.0y	SAMPLING STATION	403 / 206	80.4	36.9	0.62	0.137	716 / 380	813 / 434	920 / 493	1.99
06/11/19	06/18/19	0.0y		406 / 208	26.0	36.9	0.500	0.043	707 / 375	807 / 431	918 / 492	1.41
07/12/18	07/17/18	12.0y	OIL COLLECTION ROOT1	414 / 212	139.9	37.0	0.453	0.065	724 / 384	789 / 421	897 / 481	0.00
12/19/16	12/22/16	10.0y	SUCTION PUMP #5	423 / 217	20.2	38.6	0.463	0.100	714 / 379	820 / 438	939 / 504	1.47







Historical Comments

11/04/20	The acid number remains above normal. The acid number is a measure of the acidic compounds in the oil. Increases in the acid number are likely due to the formation of oxidation by products in the oil. This value will increase exponentially once the process begins. Tendencies are for sludge and deposits to increase and corrosion to occur if the fluid continues to be utilized beyond its limits. Although they are within normal limits, we would like to point out reducing trends in the flash point & increasing solids.
06/11/19	Based on the analysis results, it appears that the oil may have experienced acid number deterioration conditions. This may be due in part to the length of service on the oil (13 years indicated). The acid number is a measure of the acidic compounds in the oil. Increases in the acid number are likely due to the formation of oxidation by products in the oil. This value will increase exponentially once the process begins. Tendencies are for sludge and deposits to increase and corrosion to occur if the fluid continues to be utilized beyond its limits. None of the other oil degradation products are indicated. Acid Number (AN) is abnormally high.
07/12/18	Based on the analysis results, it appears that the oil may continue to experience oxidation. This may be due in part to the length of service on the oil (12 years indicated)The acid number continues to be above normal. The acid number, is a measure of the acidic compounds in the oil. Increases in the acid number are likely due to the formation of oxidation by products in the oil. This value will increase exponentially once the process begins. Tendencies are for sludge and deposits to increase and corrosion to occur if the fluid continues to be utilized beyond its limits. The oxidation level in the sample remains well above normal, however, it is remaining stable. Acid Number (AN) is abnormally high.
12/19/16	Based on the analysis results, it appears that the oil may have experienced some oxidation or possibly thermal cracking. The acid number increase is likely due to the formation of oxidation by products. Oxidation is a chemical reaction between oxygen and the components of the oil whereby the hydrocarbon in the oil turns into weak carboxylic acids and other carbon-oxygen containing species. The higher the temperature, the worse the oxidation becomes and it will feed off of Itself becoming exponentially worse over time when the additives are depicted. In a closed heat transfer system, the most probable place for fuld oxidation to occur is in the expansion tank. (without an intert gas blankel). In an open system, the fuld oxidizers apply at its operating temperature. Different oils vary considerably in their resistance to oxidation largely due to the base oil used and the antioxidant additives used in the oil. Also note increasing calcium and zinc levels. These elements at these levels are typically not associated with the product and are likely present as contaminants. (GCD) 90% Distillation Point is serverely high. Acid Number (AN) is abnormally high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.