




[Orlen Upstream Canada / 16-7-63-5w6] 5510/5610 HEAT MEDIUM


| Customer: PTRHTF20262 | System Information | Sample Information |
|--|---|---|
| Orlen upstream Canada Ltd. 850 2 St. SW Calgary, AB T2P 0R8 CA Attn: Ian Stewart Tel: E-Mail: ian.stewart@orlenustream.ca | System Volume: 10000 ltr Bulk Operating Temp: 374F / 190C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: RUSHTON | Lab No: 02605136 Analyst: Clinton Buhler Sample Date: 12/08/23 Received Date: 12/22/23 Completed: 01/03/24 Clinton Buhler Clinton.Buhler@HFSinclair.com |

Recommendation: Sample results indicate that the fluid is in suitable condition for continued service. Please re-sample in 12 months.

Comments:




| Sample Date | Received Date | Fluid Age | Sample Location | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10% | GCD 50% | GCD 90% | GCD % < 335°C |
|---------------|---------------|-----------|-----------------|-------------------|------------|------------------|-------------|--------|-----------|-----------|-----------|---------------|
| | mm/dd/yy | | | °F/°C | ppm | cSt | mg/KOH/g | %wt | °F/°C | °F/°C | °F/°C | % |
| 12/08/23 | 12/22/23 | 0.0m | | 442 / 228 | 13 | 31.2 | 0.13 | 0.053 | 732 / 389 | 818 / 437 | 920 / 493 | 1.06 |
| 11/10/23 | 12/01/23 | 0.0m | | | | | | | | | | |
| 06/17/21 | 06/28/21 | 48.0m | | 464 / 240 | 3.6 | 35.3 | 0.01 | 0.144 | 729 / 387 | 803 / 428 | 924 / 496 | 0.00 |
| 06/28/20 | 07/13/20 | 24.0m | | 468 / 242 | 36.0 | 34.9 | 0.02 | 0.042 | 739 / 393 | 821 / 438 | 921 / 494 | 0.43 |
| 10/24/19 | 11/11/19 | 30.0m | FLOAT COLUMN | 441 / 227 | 0.6 | 35.5 | 0.015 | 0.130 | 715 / 380 | 802 / 428 | 908 / 487 | 0.32 |
| Baseline Data | | | | 433 / 223 | | 34.2 | 0.03 | | 720 / 382 | 817 / 436 | 900 / 482 | 1.00 |





| Sample Date | Iron | Chromium | Nickel | Aluminum | Copper | Lead | Tin | Cadmium | Silver | Vanadium | Silicon | Sodium | Potassium | Titanium | Molybdenum | Antimony | Manganese | Lithium | Boron | Magnesium | Calcium | Barium | Phosphorus | Zinc | |
|----------------------|------|----------|--------|----------|--------|------|-----|---------|--------|----------|---------|--------|-----------|----------|------------|----------|-----------|---------|-------|-----------|---------|--------|------------|------|---|
| 12/08/23 | 7 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 11/10/23 | | | | | | | | | | | | | | | | | | | | | | | | | |
| 06/17/21 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/28/20 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 10/24/19 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Baseline Data | | | 0 | 0 | | | | | | 0 | | | 0 | 0 | | | | | 0 | | | | 0 | | |

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



| Historical Comments | |
|---------------------|---|
| 11/10/23 | *** sample was 100% water in the metal can. No thermal fluid ***Please re-sample immediately but ensure that the sample is taken from a representative point; pump discharge is ideal. Please thoroughly purge out sample point until hot heating fluid is coming out before taking the sample. Investigate the source of water contamination. Water contamination levels are severe. |
| 06/17/21 | Sample results indicate that the fluid is in suitable condition for continued service. Please re-sample in 12 months. (GCD) 90% Distillation Point is marginally high. |
| 06/28/20 | The fluid is in a good condition and suitable for further use. 10% and 90% GCD temperatures are slightly high. This is no concern at this time. Please re-sample in 12 months. (GCD) 90% Distillation Point is marginally high. |
| 10/24/19 | This was the re-sample after one of the initial August 2019 samples indicated excess water. Sample results indicate that the heat transfer fluid is suitable for continued service. Please re-sample in 12 months |

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.