




PLANT 1



Customer: PTRHTF60056	System Information	Sample Information
Glenn O Hawbaker Inc. 118 Bedrock Lane Plant 1 Bellefonte, PA 16823 US Attn: Steve Swartz Tel: (814)359-5096 E-Mail: srs@goh-inc.com	System Volume: 500 gal Bulk Operating Temp: 380F / 193C Heating Source: Blanket: Fluid: MULTITHERM IG-4 Make: AMERICAN HEATER	Lab No: 02614328 Analyst: Greg Fernandez Sample Date: 01/31/24 Received Date: 02/08/24 Completed: 02/16/24 Greg Fernandez gregory.fernandez@hfsinclair.com

Recommendation: Resample the system after startup and after at least a week of operation. Observe the flagged items for new values, with particular attention on the next reported Acid Number.

Comments: Water contamination levels are severely high. Calcium ppm levels are severely high. Acid Number (AN) is abnormally high. Viscosity @ 40°C is abnormally low. (GCD) 90% Distillation Point is marginally low. The sample exhibits characteristics of a fluid in a shutdown condition. The moisture contamination could be from ingressed water and/or accumulated condensation during the shutdown period, which could also account for the low Viscosity. That water would be expected to evaporate off upon restart. The higher Acid Number is a larger concern and would need to be monitored on the next sample. AN is less likely to return to normal levels after startup since it is a cumulative and irreversible process, hence the need to flag it as a watch point.




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
01/31/24	02/08/24	7.0y		428 / 220	1093	32.2	0.17	0.081	703 / 373	812 / 433	915 / 490	1.79
Baseline Data				441 / 227		44.0			725 / 385	820 / 438	936 / 502	5.7





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc	
01/31/24	15	0	0	1	0	0	0	0	0	0	2	12	3	0	0	0	0	0	0	0	2	44	0	2	2
Baseline Data			0	0						0			0	0					0				0		

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.