

[LSD 08-10-68-08-W6 Clairmont] HEAT MEDIUM

Customer: PTRHTF20245
 NUVISTA ENERGY LTD
 RR 93
 WEMBLY, AB T8W 0H6 CA
 Attn: Eldon Weaver
 Tel: (780)831-5603
 E-Mail: eweaver@nvaenergy.com




System Information
 System Volume: 4000 gal
 Bulk Operating Temp: 536F / 280C
 Heating Source:
 Blanket:
 Fluid: PETRO CANADA PETRO-THERM
 Make: ALCO



Sample Information
 Lab No: 02614846
 Analyst: Clinton Buhler
 Sample Date: 12/01/23
 Received Date: 02/09/24
 Completed: 02/20/24
 Clinton Buhler
 Clinton.Buhler@HFSinclair.com

Recommendation: Sample results indicate the fluid is in suitable condition for continued service. Please re-sample in 12 months.

Comments:




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
12/01/23	02/09/24	58.0m		424 / 218	12	34.1	0.01	0.047	730 / 388	814 / 435	910 / 488	1.33
12/02/22	03/10/23	4.0m		446 / 230	13.9	33.9	0.04	0.068	728 / 387	815 / 435	913 / 489	1.48
11/30/21	01/06/22	0.0m	at pump	435 / 224	15.0	34.2	0.05	0.036	732 / 389	815 / 435	910 / 488	0.92
09/15/21	12/13/21	0.0m	RETURN LOOP	442 / 228	14.7	34.3	0.02	0.040	728 / 387	814 / 435	909 / 487	1.78
09/15/21	10/26/21	0.0m	return loop	464 / 240	7.2	34.2	0.04	0.037	732 / 389	815 / 435	909 / 487	1.01
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
12/01/23	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
12/02/22	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
11/30/21	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	3	0	0	0	0	0
09/15/21	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
09/15/21	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Baseline Data			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments

12/02/22	Sample results indicate the fluid is in suitable condition for continued service. Please re-sample in 12 months.
11/30/21	Sample results indicate the fluid is in suitable condition for continued service. Please re-sample in 12 months
09/15/21	Sample results indicate that the fluid is in suitable condition for continued service. Please include time on oil for next analysis. Please re-sample in 12 months
09/15/21	Sample results indicate that the fluid is in suitable condition for continued service. Please re-sample in 12 months

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.