




## [D-4 Morris plant] LISBON IL



Customer: PTRHTF30107	System Information	Sample Information
D-CONSTRUCTION 16805 QUARRY RD MORRIS, IL 60450 US Attn: Chris Lenzie Tel: (815)405-6831 E-Mail: clenzie@sandenoinc.com	System Volume: 400 g Bulk Operating Temp: 350F / 177C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: HEAT TECH	Lab No: 02617271 Analyst: Yvette Trzcinski Sample Date: 02/08/24 Received Date: 02/21/24 Completed: 03/06/24 Yvette Trzcinski yvette.trzcinski@HFSinclair.com

Recommendation: Continuing to see some thermal degradation the low boilers has increased as well as the acid number and insolubles. Product is acceptable for continued use resample in 6-9 months

Comments:




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
02/08/24	02/21/24	0.0y		446 / 230	116	34.5	0.39	0.251	718 / 381	815 / 435	921 / 494	1.18
12/07/22	02/28/23	0.0y		432 / 222	17.3	35.0	0.38	0.207	723 / 384	818 / 436	918 / 492	0.87
03/24/22	03/30/22	3.0y	RETURN LINE	428 / 220	28.9	34.7	0.31	0.109	723 / 384	818 / 436	923 / 495	0.48
12/14/21	12/30/21	4.0y	return, before pump	442 / 228	19.4	34.9	0.36	0.263	720 / 382	814 / 435	921 / 494	0.58
12/15/20	12/24/20	2.0y	Return	450 / 232	18.8	34.5	0.25	0.082	723 / 384	816 / 435	922 / 494	0.29
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc	
02/08/24	13	0	0	0	1	0	0	0	0	0	2	2	0	0	0	0	0	0	0	0	0	0	0	0	1
12/07/22	2	0	0	0	1	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	0	0	0	1
03/24/22	4	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0
12/14/21	1	0	0	0	2	1	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0
12/15/20	0	0	0	0	0	0	0	0	0	0	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Baseline Data			0	0						0			0	0					0				0		

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
12/07/22	Some continued oil oxidation is occurring as evidence of the increase in the Acid number and the Pentane Insolubles and the GCD 90% boiling point temperature. Fluid is acceptable for continued use resample in 6-12 months. Acid Number (AN) is abnormally high. (GCD) 90% Distillation Point is marginally high.
03/24/22	Acid number is slightly high but all other parameters look good. Continue to use an resample at next scheduled interval. Acid Number (AN) is abnormally high. (GCD) 90% Distillation Point is marginally high.
12/14/21	There is some degradation and oxidation occurring in the system. The Acid number is increasing as well as the boiling point - GCD 90%. Fluid is suitable for continued use but resample in 12 months to monitor acid number and degradation level. Acid Number (AN) is abnormally high. (GCD) 90% Distillation Point is marginally high.
12/15/20	Sample specifications are all within acceptable limits and product looks good for continued service. Re-sample in 6-12 months. (GCD) 90% Distillation Point is marginally high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.