





CARGILL MEAT (THAILAND) SARABURI

Customer: PTRHTF60010

SYNLUBE INTERNATIONAL CO LTD 76/1 MOO.7 THACHIN

MUANG SAMUTSAKHON, 74000 TH

Attn: CHERNPORN CHOBKUI

Tel: 034421290

E-Mail: chernporn@synlube.co.th

System Information

System Volume: 10000 ltr

Bulk Operating Temp: 554F / 290C

Heating Source:

Blanket:

Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID

Make: WANSON

Sample Information

Lab No: 02618526

Analyst: Bill Quesnel CLS, OMA II, MLA-

III,LLA-I


Sample Date: 02/09/24 Received Date: 02/27/24 Completed: 03/05/24

Bill Quesnel CLS, OMA II, MLA-III, LLA-I

Recommendation: We recommend that you vent the expansion tank to remove low boilers which assists in restoring the flash point of the fluid. We recommend an early resample to monitor this condition.

Comments: (GCD) 90% Distillation Point is abnormally high. COC Flash Point is abnormally low. Visc @ 40°C is abnormally low.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.