

## **TPC 2580 LN-ES**

## Customer: PTRHTF60066

MCCAIN APPETIZERS EUROPE DE POORT 27

RILLAND ZEELAND, 4411 NL

Attn: Wilbert Snijers

Tel:

E-Mail: w.snijers@klt.nl

## System Information

System Volume: 8000 ltr

Bulk Operating Temp: 473F / 245C

Heating Source:

Blanket:

Fluid: FRAGOLTHERM FG-35

Make: WANSON

## Sample Information

Lab No: 02626253

Analyst: Bill Quesnel CLS,OMA II,MLA-


III,LLA-I


Sample Date: 03/28/24 Received Date: 04/02/24 Completed: 04/19/24

Bill Quesnel CLS,OMA II,MLA-III,LLA-I

Recommendation: We recommend that you vent the expansion tank to remove low boilers which assists in restoring the flash point of the fluid. The fluid is suitable for further service. Resample at the next service interval to monitor.

Comments: (GCD) 90% Distillation Point is severely high. COC Flash Point is marginally low.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.