

# SILANE 3.0 DISTILLATION

**Customer: PTRHTF10093**  
 REC GROUP  
 3322 ROAD N.N.E.  
 MOSES LAKE, WA 98837 US  
 Attn: Chris Fuller  
 Tel: (509)793-0723  
 E-Mail: chris.fuller@recsilicon.com




**System Information**  
 System Volume: 700 gal  
 Bulk Operating Temp: 300F / 149C  
 Heating Source:  
 Blanket:  
 Fluid: PETRO CANADA CALFLO AF  
 Make: CCI


**Sample Information**  
 Lab No: 02626261  
 Analyst: Ron LeBlanc  
 Sample Date: 03/24/24  
 Received Date: 04/02/24  
 Completed: 04/23/24  
 Ron LeBlanc  
 Ronald.LeBlancSr@HFSinclair.com

Recommendation: The sample shows phosphorus depleted to 21 ppm. the new typical is 270 ppm. This indicates the antioxidant packages can be depleted below acceptable operating ranges. When R&D broke down 3.0 last year it was found the antioxidant packages were depleted and suggested the oil be changed to obtain maximum heat transfer qualities.

Comments:




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
03/24/24	04/02/24	180.0m		417 / 214	6	30.2	0.02	0.037	698 / 370	799 / 426	894 / 479	1.91
07/15/23	07/20/23	171.0m	mole sieve preheater	446 / 230	4.5	39.3	0.06	0.044	714 / 379	816 / 436	936 / 502	1.14
06/29/23	07/05/23	0.0m	expansion tank	406 / 208	6.6	30.2	0.05	0.041	697 / 370	800 / 427	895 / 480	2.25
06/29/23	07/05/23	171.0m	expansion tank	406 / 208	6.0	30.1	0.05	0.046	696 / 369	799 / 426	895 / 479	2.25
10/15/18	11/06/18	114.0m		403 / 206	15.2	30.1	0.03	0.045	690 / 366	796 / 425	890 / 477	2.39
<b>Baseline Data</b>				435 / 224		32.7	0.03		693 / 367	790 / 421	887 / 475	2.5





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc	
03/24/24	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	21	0	
07/15/23	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	297	2
06/29/23	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	22	1	
06/29/23	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	22	1	
10/15/18	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	19	0	
Baseline Data			0	0						0			0	0					0				270		

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
07/15/23	The viscosity is abnormally high. The GCD 90% Distillation point is severely high indicating increase in viscosity. Pentane insolubles is elevated compared to previous sample. Sludge may be forming causing 90% Distillation Point to increase. Consider taking another sample. Purge plenty of oil before taking sample. Make sure oil is hot when pulling the sample. (GCD) 90% Distillation Point is severely high. Visc @ 40°C is abnormally high.
06/29/23	Sample looks excellent. Resample at normal interval.
06/29/23	Sample looks excellent. Resample at next normal interval.
10/15/18	Sample is normal. Re-sample at regular interval.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.