

[1-24-052-20W5] H-500

Customer: PTRHTF20103

CANADIAN NATURAL RESOURCES

(CNRL)

P.O. BOX 6808

EDSON, AB T7E 1L5 CA

Attn: Rod Bailer

Tel:

E-Mail: rod.bailer@cnrl.com

System Information

System Volume: 0 ltr

Bulk Operating Temp: 518F / 270C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make:

Sample Information


Lab No: 02632628 Analyst: Clinton Buhler Sample Date: 04/26/24 Received Date: 05/01/24 Completed: 05/13/24

Clinton Buhler


Clinton.Buhler@HFSinclair.com

Recommendation: Sample results indicate the fluid is in suitable condition for continued service. Please re-sample in 12 months

Comments:



Report ID: [02632628] (Generated: 05/13/2024 11:11:24) - Page 1 - Copyright 2024 Wearcheck Inc. All Rights Reserved.



monitor the condition of the oil. Please let me know the exact volume of the system so that I can update our records accordingly. (GCD) 90% Distillation Point is abnormally high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.