

WANSON TPC 400B

Customer: PTRHTF40070

BETINA BV WHEEWEG 63 GOOR 7471EV GOOR, 7471EV NL Attn: WILBERT SNIJERS

Tel:

E-Mail: w.snijers@klt.nl

System Information
System Volume: 1000 ltr

Bulk Operating Temp: 240F / 116C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make: WANSON

Sample Information

Lab No: 02634209

Analyst: Bill Quesnel CLS, OMA II, MLA-

III,LLA-I


Sample Date: 05/02/24 Received Date: 05/08/24 Completed: 05/24/24


Bill Quesnel CLS,OMA II,MLA-III,LLA-I

Recommendation: Fluid fit for further use. Send in new sample at next scheduled interval.

Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	300 GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
05/02/24	05/08/24	15.5y		448 / 231	23	34.2	0.26	0.169	717 / 380	810 / 432	911 / 488	1.45
09/11/20	09/17/20	12.0y		424 / 218	53.0	33.6	0.23	0.138	720 / 382	809 / 432	907 / 486	0.94
11/22/12	03/20/13	0.0y		446 / 230	27.5	33.4	0.04	0.108	712 / 378	805 / 429	903 / 484	1.29
11/19/09	11/19/09			437 / 225	99	32.7	0	0.02	718 / 381		916 / 491	1
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.