

[KEYERA PARTNERSHIP / 3-12-46-14W5] PLANT 2

Customer: PTRHTF30084
 Keyera Partnership Brazeau River Ga...
 Box 7318
 Drayton Valley, AB T7A 1S5 CA
 Attn: Gareth Buchanan
 Tel: (780)913-1176
 E-Mail: gareth_buchanan@keyera.com




System Information
 System Volume: 14000 ltr
 Bulk Operating Temp: 455F / 235C
 Heating Source:
 Blanket:
 Fluid: PETRO CANADA CALFLO AF
 Make: PETROTHERM ENG.



Sample Information
 Lab No: 02639527
 Analyst: Lyle Dach
 Sample Date: 05/26/24
 Received Date: 06/03/24
 Completed: 06/10/24
 Lyle Dach
 lyle.dach@HFSinclair.com

Recommendation: Sample results indicate that the fluid is in good condition and is suitable for continued service. Resample in 12 months.

Comments:




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
05/26/24	06/03/24	48.0m	PUMP DISCHARGE	428 / 220	12	31.3	0.04	0.084	701 / 372	803 / 429	901 / 483	2.37
04/01/24	04/10/24	36.0m		435 / 224	27	31.3	0.02	0.051	692 / 367	788 / 420	909 / 487	2.15
02/03/24	02/13/24	36.0m		435 / 224	30	31.1	0.05	0.043	701 / 372	803 / 428	899 / 482	2.42
11/30/23	12/08/23	0.0m	HOH #2 pump	439 / 226	21	31.2	0.10	0.026	676 / 358	787 / 420	915 / 491	5.08
10/01/23	10/11/23	40.0m	AFTER PUMP	457 / 236	27.7	29.6	0.07	0.061	697 / 370	799 / 426	899 / 482	2.52
Baseline Data				435 / 224		32.7	0.03		693 / 367	790 / 421	887 / 475	2.5





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
05/26/24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	44	0
04/01/24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3	0	0	0	45	0
02/03/24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3	0	0	0	46	0
11/30/23	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	4	0	0	0	46	0
10/01/23	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	4	0	0	0	49	0
Baseline Data			0	0						0			0	0					0				270	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments

04/01/24	Sample results indicate that the fluid is in suitable condition for continued service. Resample in 12 months. (GCD) 90% Distillation Point is marginally high.
02/03/24	Sample results indicate that the fluid is in suitable condition for continued service. Resample in 12 months.
11/30/23	Sample results indicate that the fluid is in suitable condition for continued service. 90% distillation point is slightly elevated, confirm blanket gas is functioning properly as fluid oxidizing could cause the increase. Resample in 12 months. (GCD) 90% Distillation Point is abnormally high.
10/01/23	Sample results indicate that the fluid is in suitable condition for continued service. Resample in 12 months.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.