

[9-10-74-11W6] OLD BOILER

Customer:

WEARCHECK CANADA INC. C8-1175 Appleby Line BURLINGTON, ON L7L 5H9 CA

Attn: Dorian Anderson

Tel:

E-Mail:

dorian.anderson@wearcheck.com

System Information
System Volume: Itr

Bulk Operating Temp: Not Specified

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make:

Sample Information

Lab No: 02645056

Analyst: Bill Quesnel CLS, OMA II, MLA-

III,LLA-I


Sample Date: 06/25/24 Received Date: 07/02/24 Completed: 07/11/24

Bill Quesnel CLS,OMA II,MLA-III,LLA-I

Recommendation: *** NOTE: GCD/SimDis values askew due to high water content ***

Comments: Water contamination levels are severely high. Water contamination levels are severely high. ppm Water contamination levels are severely high. Potassium ppm levels are abnormally high. (GCD) % < 335°C is severely high. (GCD) 10% Distillation Point is severely low. (GCD) 50% Distillation Point is severely low. (GCD) 90% Distillation Point is severely low. Visc @ 40°C is severely low. Acid Number (AN) is abnormally high.





WearCheck Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it.