


H-60


Customer: PTRHTF20208	System Information	Sample Information
Plains Midstream Canada	System Volume: 1000 ml	Lab No: 02645057
PO Box 3210	Bulk Operating Temp: 482F / 250C	Analyst: Terry Veenstra
Range Road 221	Heating Source:	Sample Date: 06/26/24
Fort Saskatchewan, AB T8L 2T2 CA	Blanket:	Received Date: 07/02/24
Attn: Marlon Gonzalez	Fluid: PETRO CANADA PETRO-THERM	Completed: 07/03/24
Tel: (780)992-2724	Make:	Terry Veenstra
E-Mail:		terry.veenstra@HFSinclair.com


Recommendation: Sample indicates that oil is in good condition and suitable for further use. Resample in 6 months.

Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
06/26/24	07/02/24	12.0m	after filtering syst	446 / 230	18	34.7	0.02	0.013	724 / 384	814 / 435	912 / 489	1.10
12/20/23	12/27/23	7.0m		442 / 228	158	34.6	0.02	0.042	723 / 384	814 / 434	912 / 489	1.09
07/18/23	07/27/23	0.0m	after filtering syst	457 / 236	64.9	34.6	0.02	0.039	726 / 385	815 / 435	910 / 488	1.00
09/20/22	09/26/22	25.0m	AFTER FILTERING	390 / 199	17.5	34.9	0.01	0.037	668 / 353	792 / 422	880 / 471	4.69
04/12/22	04/18/22	25.0m	after filtering syst	446 / 230	10.6	26.2	0.01	0.071	669 / 354	793 / 423	882 / 472	4.46







Response 6,000

5,000

4 000


3,000

2,000

1.000



6



Apr12/22

Sep20/22

Jul18/23

Apr28/21

Jun26/24

Dec20/23

Dec4/18

Historical Comments

Percent Recovered

12/20/23	Water content is increasing however sample indicates that oil is in good condition and suitable for further use. Resample in 6 months.
07/18/23	Sample indicates that oil is in good condition and suitable for further use. Resample in 6 months.
09/20/22	This sample indicates that the oil is in good condition and suitable for continued use. Resample in 6 months.
04/12/22	This oil viscosity is 26.2 cSt @ 40°C so is a blend of Thermoil 32 and PetroTherm. The TAN is still quite low at 0.01mgKOH/g and the flash point is still good @ 230°C indicating the fluid is in pretty good shape. The Pentane Insolubles are at0.071% which suitable for further use.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.