

[3-6-39-11W5] WESTBRICK

Customer: PTRHTF20243
 CFR CHEMICALS
 38451 RRZZ
 RED DEER, AB T4E 2N6 CA
 Attn: Andrew Schacher
 Tel: (780)982-8478
 E-Mail: aschacher@cfrchemicals.com




System Information
 System Volume: 5000 ltr
 Bulk Operating Temp: 185F / 85C
 Heating Source:
 Blanket:
 Fluid: PETRO CANADA PETRO-THERM
 Make:



Sample Information
 Lab No: 02648260
 Analyst: Lyle Dach
 Sample Date: 07/11/24
 Received Date: 07/16/24
 Completed: 07/17/24
 Lyle Dach
 lyle.dach@HFSinclair.com

Recommendation: This sample confirms the elevated acid number that we saw in March. Iron levels and pentane insolubles are low, it does not appear that the elevated acid number is causing corrosive wear. The AN levels have dropped slightly from previously, was the system topped up with fresh oil? Overall the fluid appears to be in reasonable condition but the acid number is still a concern and should be monitored. Sweetening does help but for a system of this size it maybe better to plan to replace the fluid instead of sweetening. Draining, cleaning the system and installing new fluid will have a better service life than fluid that is used to sweeten a system. Acid number does increase exponentially and has tendencies to cause increased sludge deposits and system corrosion. Resample in 6 months.

Comments: Acid Number (AN) is abnormally high.




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
07/11/24	07/16/24	0.0y		442 / 228	34	33.4	0.61	0.069	699 / 371	802 / 428	902 / 484	2.73
03/06/24	03/19/24	3.0y		408 / 209	62	33.6	0.74	0.369	702 / 372	802 / 428	902 / 484	1.61
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
07/11/24	1	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	23	0
03/06/24	5	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	31	0
Baseline Data			0	0						0		0	0					0				0		

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments

03/06/24	Overall the fluid appears to be in reasonable condition the fluids acid number is elevated to a level where fluid sweetening should be considered. Acid number does increase exponentially and has tendencies to cause increased sludge deposits and system corrosion. Resample to confirm these results. Acid Number (AN) is abnormally high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.