



MAIN SYSTEM

Customer: PTRHTF10035

CERTAINTEED - SAINT GOBAIN 2701 E. ROOSEVELT RD LITTLE ROCK, AR 72206 USA Attn: MICHAEL MCNULTY

Tel: (501)375-9173

E-Mail: michael.e.mcnulty@saint-

gobain.com

System Information

System Volume: 2600 gal

Bulk Operating Temp: 500F / 260C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO AF

Make: HEATEC

Sample Information

Lab No: I-635169


Analyst: Gaston Arseneault Sample Date: 03/12/12 Received Date: 03/19/12 Completed: 03/28/12

To discuss this report contact Gaston


Arseneault at 973-986-6503

Recommendation: This is the first sample since the big clean up in 2010. The oil appears relatively good, viscosity and Total Acid Number being normal. We see a certain amount of calcium, which could come from detergents from the pre-cleaner used in the operation. Although the solids contamination is also high which could indicate the calcium may come from airborne dust from your filler pile. We will send a reminder in December to re-sample.

Comments: Water is at a MINOR LEVEL. GRAVIMETRIC SOLIDS is SIGNIFICANTLY HIGH (CAUTION LEVEL - 3) Simulated distillation 10% boiling point is moderately low. Simulated distillation 90% boiling point is severely high. The amount of low boilers is at a moderate level, characterizing the level of thermal degradation or possible dilution with a lighter oil (if applicable).







Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.