

HEATER 4

0.00

Feb7/21

System Information	Sample Information
System Volume: 0 gal	Lab No: 05455337
Bulk Operating Temp: Not Specified	Analyst: Doug Bogart
Heating Source:	Sample Date: 01/30/22
Blanket:	Received Date: 01/31/22
Fluid: NOT GIVEN	Completed: 02/10/22
Make:	Doug Bogart
	dougb@wearcheckusa.com
	System Volume: 0 gal Bulk Operating Temp: Not Specified Heating Source: Blanket: Fluid: NOT GIVEN

Recommendation: This is a baseline read-out on the submitted sample.

Comments: An increase in the lead level is noted. The water content is negligible. There is no indication of any contamination in the fluid. The AN level is acceptable for this fluid.



220

Feb7/21

Jan30/22

Jan30/22

Feb7/21

50

Jan30/22



Elemental anaysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]

GCD Spectrum

Historical Comments	
02/07/21	This is a baseline read-out on the submitted sample. All component wear rates are normal. There is a light concentration of water present in the fluid. Moderate concentration of visible dirt/debris present in the fluid. The AN level is acceptable for this fluid.

WearCheck Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it.