

NOT GIVEN TR0001116

Customer:	System Information	Sample Information
STAKER PARSON	System Volume: 0 qts	Lab No: 05900700
33 S 900 E	Bulk Operating Temp: Not Specified	Analyst: Doug Bogart
BRIGHAM CITY, UT 84403 US	Heating Source:	Sample Date: 07/12/23
Attn: Service Manager	Blanket:	Received Date: 07/17/23
Tel:	Fluid: PETRO CANADA PETRO-THERM	Completed: 08/03/23
E-Mail:	Make:	Doug Bogart
		dougb@wearcheckusa.com

Recommendation: The fluid is highly oxidized as indicated by the increase in the fluid boiling points, and the large increase in viscosity. As a result the system heating efficiency will be greatly reduced. Recommend schedule the system for a fluid changeout in the near future. Distillation, Solids and evaluation performed at performed at WearCheck Canada.

Comments: Pentane Insolubles levels are severely high. (GCD) 90% Distillation Point is severely high. Visc @ 40°C is severely high. Acid Number (AN) is abnormally high. (GCD) 50% Distillation Point is abnormally high. Visc @ 100°C is abnormally high. Viscosity Index (VI) is abnormally high. (GCD) 10% Distillation Point is marginally high.











