



## SILO #2

Customer: PTRHTF30143	System Information	Sample Information
E.I. Dupont Canada Thetford 1045 rue Monfette N. Thetford Mines, QC G6G 7K7 Canada Attn: John Parra Tel: (438)338-8567 E-Mail: john.parra@dupont.com	System Volume: 45 gal Bulk Operating Temp: Not Specified Heating Source: Blanket: Fluid: SHELL THERMIA OIL C Make:	Lab No: 02355356 Analyst: Pierre Castagne Sample Date: 05/08/20 Received Date: 05/22/20 Completed: 05/27/20 Pierre Castagne pierre.castagne@petrocanadalsp.com

Recommendation: La teneur en eau est élevé (1063.7 ppm). L'indice d'acidité est élevé (0.58). Les fractions légère (GCD @10%) (430.4). il y a début des fractions légère. Les (GCD % < 335C) sont (0.35). Nous vous recommandons de nettoyer, rincer et mettre une nouvelle charge de fluide caloporteur.

Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
05/08/20	05/22/20	7y		493 / 256	1063.7	66.6	0.58	0.188	807 / 430	873 / 467	963 / 517	0.35
Baseline Data				500 / 260		64	0.005		777 / 414	867 / 464	964 / 518	0.00



