

LIEBHERR

CONSTRUCTION EQUIPMENT



72367 TANK DRAIN - Drain Diesel Fuel

Sample No: LH0277731

Oil Type: No.2 DIESEL FUEL (HIGH-SULPHUR)



SAMPLE INFORMATION

Sample Number		LH0277731	---	---	---
Sample Date		20 Nov 2023	---	---	---
Machine Hours		0	---	---	---
Sample Status		ABNORMAL	---	---	---



FUEL CONDITION

Sulfur	ppm	518	---	---	---
Visc @ 40°C	cSt	2.6	---	---	---



CONTAMINATION

Lead	ppm	0	---	---	---
Nickel	ppm	0	---	---	---
Aluminum	ppm	0	---	---	---
Vanadium	ppm	0	---	---	---
Silicon	ppm	18	---	---	---

LIEBHERR CANADA LTD.

1015 SUTTON DRIVE
BURLINGTON, ON
CA L7L 5Z8

Contact: Joseph Rodgers
joseph.rodgers@liebherr.com
T: (905)319-9222
F: (905)319-6622

Diagnosis


We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. {not applicable} There is no indication of any contamination in the component (unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot: LIEMIS
Unique No: 5683128
Signed: Kevin Marson
Report Date: 22 Nov 2023



GRAPHS

Pensky-Martens Flash Point (°C)



GCD Spectrum

