



DEGRADATION

Sample Rating Trend



Machine Id
K601
 Component
Natural Gas Compression Engine
 Fluid
PETRO CANADA SENTRON LD 3000 (--- LTR)




OIL ANALYSIS REPORT

Sample		Wear Metals												Contaminants			Additives											
Sample Number	Sample Date	Iron	Chromium	Nickel	Titanium	Silver	Aluminum	Lead	Copper	Tin	Antimony	Vanadium	Beryllium	Cadmium	Silicon	Sodium	Potassium	Boron	Barium	Molybdenum	Manganese	Magnesium	Calcium	Phosphorus	Zinc	Sulfur	Lithium	
		>14	>3	>5		>5	>5	>8	>5	>3					>180	>20	>20	5	1	2	1	5	1220	298	350	1995		
PC0089491	21 Jun 2024	2	0	<1	0	0	2	0	<1	0	0	0	0	0	<1	<1	<1	1	0	<1	0	8	1510	293	385	2178	<1	
PC0089485	15 May 2024	2	0	0	0	0	1	0	<1	0	0	0	0	0	0	<1	<1	<1	0	0	0	0	10	1462	291	368	2099	<1
PC0089478	21 Apr 2024	1	0	0	0	0	<1	0	<1	0	0	0	0	0	0	<1	<1	<1	0	0	0	0	8	1425	282	352	2061	<1
PC0089509	27 Mar 2024	1	0	0	0	0	<1	0	<1	0	0	0	0	0	0	<1	0	1	0	0	0	8	1403	283	349	2110	<1	
PC0085507	16 Feb 2024	1	0	0	0	0	2	0	<1	0	0	0	0	0	1	<1	<1	<1	0	<1	0	0	8	1349	283	333	2222	<1
PC0085493	17 Jan 2024	<1	0	<1	0	0	1	0	<1	0	0	0	0	0	1	<1	<1	<1	0	0	0	0	7	1231	257	303	2068	<1


Sample					Physical Tests						Other Tests										
Sample Number	Machine Age	Oil Age	Oil Changed	Filter Changed	Visc @ 40°C	Visc @ 100°C	Viscosity Index (VI)	Water	Glycol	Fuel	Oxidation (Diff)	Nitration (Diff)	Sulfation (Diff)	Acid Number (AN)	Base Number (BN)	Particles >4µm	Particles >6µm	Particles >14µm	Oil Cleanliness		
	hrs	hrs		---	124.3	13.7	106	>0.1		>4.0	< 25	< 25		0.86	---	---	---	---	---	---	---
PC0089491	33350	0	Not Changd	---	126	13.7	105	NEG	NEG	<1.0	13	7.3	11.9	3.90	---	---	---	---	---	---	---
PC0089485	32469	0	Not Changed	---	126	13.6	103	NEG	NEG	<1.0	11.6	6.8	11.2	1.54	---	---	---	---	---	---	---
PC0089478	0	0	N/A	---	124	13.6	105	NEG	NEG	<1.0	9.6	5.9	8.7	1.31	---	---	---	---	---	---	---
PC0089509	31604	23387	N/A	---	122	13.3	103	NEG	NEG	<1.0	8.8	5.7	7.8	1.34	---	---	---	---	---	---	---
PC0085507	30354	0	Not Changed	---	120	13.2	104	NEG	NEG	<1.0	6.2	4.7	5.8	0.97	---	---	---	---	---	---	---
PC0085493	29659	0	Not Changed	---	120	13.2	104	NEG	NEG	<1.0	2.8	2.2	2.5	0.41	---	---	---	---	---	---	---

Recommendations		Interpretation	
21 Jun 2024	The oil is near the end of it's useful service life, recommend schedule an oil change. Resample at the next service interval to monitor. NOTE: Acid number was run 3x to confirm.	21 Jun 2024	All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is above the recommended limit. The oil is no longer serviceable.
15 May 2024	Resample at the next service interval to monitor.	15 May 2024	All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


FT-IR (Differential)




FT-IR (Direct Trend)




Viscosity @ 40°C




Ferrous Alloys




Non-ferrous Metals



Viscosity @ 100°C



Acid Number



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0089491 **Received** : 02 Jul 2024
Lab Number : 02644797 **Tested** : 08 Jul 2024
Unique Number : 5802336 **Diagnosed** : 08 Jul 2024 - Bill Quesnel
Test Package : GEO 2 (Additional Tests: TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

NuVista Energy
 10508 67 Ave, #201
 Grande Prairie, AB
 CA T8W 0K8
 Contact: Eldon Weaver
 eweaver@nvaenergy.com

T:
 F: