




Machine Id K603 Component Reciprocating Compressor PETRO CANADA SENTRON LD SYNTHETIC BLEND (--- LTR)



OIL ANALYSIS REPORT

| Sample | Wea | Wear Metals | | | | | | | | | | Contan | | | | inants Additives | | | | | | | | | | | | |
|------------------|---|---------------------------|------------|-------------------|--------|----------------|-----------------|-----------|------------|--------|----------------|--|---|-----------------|-----------------|------------------|---------------------|---------------------|-----------|---------|------------|-----------|------------------|----------|------------|-------------|--------|---------|
| Sample Number | Sample Date | | Iron | Chromium | Nickel | Titanium | Silver | Aluminum | Lead | Copper | Tin | Antimony | Vanadium | Beryllium | Cadmium | Silicon | Sodium | Potassium | Boron | Barium | Molybdenum | Manganese | Magnesium | Calcium | Phosphorus | Zinc | Sulfur | Lithium |
| | | | >50 | >10 | | | | >25 | >25 | >50 | >15 | | | | | >25 | | >20 | 0 | 0 | 0 | 0 | 3 | 1402 | 246 | 305 | 2310 | |
| PC0089486 | 28 May 2024 | | 1 | 0 | <1 | 0 | 0 | 1 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 2 | <1 | <1 | <1 | 0 | 0 | 0 | 7 | 1178 | 249 | 307 | 1952 | <1 |
| PC0089486 | 28 May 2024 | | <1 | 0 | <1 | 0 | 0 | 1 | <1 | 6 | <1 | 0 | 0 | 0 | 0 | 1 | <1 | 0 | 2 | 0 | 0 | 0 | 6 | 1330 | 247 | 302 | 2147 | <1 |
| PC0089513 | 15 May 2024 | | <1 | 0 | 0 | 0 | 0 | 1 | <1 | 15 | <1 | 0 | 0 | 0 | 0 | <1 | <1 | 0 | 1 | 0 | 0 | 0 | 7 | 1299 | 251 | 296 | 2162 | <1 |
| PC0085513 | 21 Apr 2024 | | <1 | 0 | 0 | 0 | 0 | <1 | <1 | 13 | <1 | 0 | 0 | 0 | 0 | <1 | <1 | 0 | 1 | 0 | 0 | 0 | 7 | 1303 | 241 | 289 | 2097 | <1 |
| PC0089504 | 27 M | ar 2024 | <1 | 0 | 0 | 0 | 0 | 1 | <1 | 12 | 0 | 0 | 0 | 0 | 0 | <1 | <1 | 0 | 1 | 0 | 0 | 0 | 7 | 1301 | 243 | 291 | 2122 | <1 |
| PC0085504 | 16 Fe | eb 2024 | <1 | 0 | 0 | 0 | <1 | 1 | <1 | 12 | <1 | <1 | 0 | 0 | 0 | 1 | <1 | <1 | 1 | 0 | <1 | 0 | 7 | 1307 | 248 | 290 | 2287 | <1 |
| Sample | | | | | F | Physical Tests | | | | | | | Ot | ner Te | ests | | | | | | | | | | | | | |
| Sample Number | Machine Age | Machine Age Oil Age | | Filter Changed | | Visc @ 40°C | Visc @ 100°C | Viecoeity | Index (VI) | Water | | 200 | Fuel | Oxidation(Diff) | Nitration(Diff) | Sulfation(Diff) | Acid Number (AN) | Base Number (BN) | Particles | | Particles | wp< | Particles | >14µm | ïÖ | Cleanliness | | |
| | hrs | hrs | | | 1 | 106.0 | 15.6 | 1 | 153 | >0.1 | | | | | | | 1.0 | | >1 | 300 | >6 | 40 | >16 | 60 | >17/1 | 6/14 | | |
| PC0089486 | 30573 | 0 | Changed | | | 117 | 13.2 | 1 | 107 | 0.003 | | - | | | | | 0.20 | | 27 | '040 | 1433 77 | | 7 | 22/18/13 | | | | |
| PC0089486 | 30573 | 0 | Changed | | | 107 | 15.4 | 1 | 151 | 0.00 | | | | | | | 0.58 | | 5 | 565 169 | | 12 | 12 16/15 | | 5/11 | | | |
| PC0089513 | 30268 | 30268 0 | | | | 106 | 15.1 | 1 | 149 | 0.003 | 03 | | | | | | 0.49 | | 7 | '17 | 177 | | 10 | | 17/15/10 | | | |
| PC0085513 | 0 | 0 | N/A | | | 106 | 15.1 | 1 | 149 | 0.009 | | - | | | | | 0.54 | | | | | | | | | | | |
| PC0089504 | 28977 | 27655 | N/A | | | 106 | 15.2 | 1 | 150 | 0.003 | | | | | | | 0.51 | | 3 | 17 | 6 | 9 | 9 | | 15/13 | 3/10 | | |
| PC0085504 | 28238 | 0 | Not Changd | | | 106 | 15.1 | 1 | 149 | 0.008 | | - | | | | | 0.48 | | 2 | 240 | 7 | 9 | 11 | | 15/13 | 3/11 | | |
| Recommendations | | | | | | | | | | | Interpretation | | | | | | | | | | | | | | | | | |
| 28 May 2024 | The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. Diagnostician's Note: The viscosities were tested twice (13.1 and 13.2 cSt @ 100°C, 117 and 118 cSt @ 40°C), however the viscosities for the current sample are normal. | | | | | | | | | | 28 | All component wear rates are normal. There is a moderate amount of silt (partic < 14 microns in size) present in the oil. The water content is negligible. Viscosity sample indicates oil is within SAE 40 range, advise investigate. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant can be reduced to acceptable levels. | | | | | | | | | | | cosity vel is | of | | | | |
| 28 May 2024 | Resample at the next service interval to monitor. | | | | | | | | | | | 28 | All component wear rates are normal. The system cleanliness is acceptable your target ISO 4406 cleanliness code. The water content is negligible. The 28 May 2024 and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. condition of the oil is suitable for further service. | | | | | | | | | | The sy | stem | | | | |

Charts & Pictures





CALA ISO 17025:2017 Accredited

Laboratory

Laboratory: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9

Sample No. : PC0089486 Lab Number : 02644885

Received Unique Number : 5802424

Tested : 04 Jul 2024

Diagnosed: 04 Jul 2024 - Bill Quesnel

: 02 Jul 2024

Test Package : GEO 2 (Additional Tests: KF)

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

NuVista Energy

10508 67 Ave, #201 Grande Prairie, AB CA T8W 0K8 Contact: Eldon Weaver

eweaver@nvaenergy.com

T: