


OIL ANALYSIS REPORT

[71126180] PC TURBOFLO EP 32

Component New (Unused) Oil

PETRO CANADA TURBOFLO EP 32 (--- GAL)



DIAGNOSIS

Recommendation

This is the baseline readout on this new (unused) oil. The fluid is suitable for service.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. There is no indication of any contamination in the new (unused) oil.


Fluid Condition

Linear Sweep Voltammetry (RULER - ASTM D6971) testing indicates normal levels of antioxidants present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for service.

AL)			Sep2011	Jun2019		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC	PC	
Sample Date		Client Info		10 Jun 2019	23 Sep 2011	
Machine Age	сус	Client Info		0	0	
Oil Age	сус	Client Info		0	0	
Oil Changed	-,-	Client Info		N/A	Changed	
Sample Status				NORMAL	NORMAL	
CONTAMINATI	ION	method	limit/base	current	history1	history2
Water		WC Method		NEG	NEG	
WEAR METALS	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)		0	0	
Chromium	ppm	ASTM D5185(m)		0	0	
Nickel	ppm	ASTM D5185(m)		0	0	
Titanium	ppm	ASTM D5185(m)		0	0	
Silver	ppm	ASTM D5185(m)		0	0	
Aluminum	ppm	ASTM D5185(m)		0	0	
Lead	ppm	ASTM D5185(m)		<1	<1	
Copper	ppm	ASTM D5185(m)		0	0	
Tin	ppm	ASTM D5185(m)		0	0	
Antimony	ppm	ASTM D5185(m)		0	<1	
Vanadium	ppm	ASTM D5185(m)		0	0	
Beryllium	ppm	ASTM D5185(m)		0	0	
Cadmium	ppm	ASTM D5185(m)		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		0	0	
Barium	ppm	ASTM D5185(m)		0	0	
Molybdenum	ppm	ASTM D5185(m)		0	0	
Manganese	ppm	ASTM D5185(m)		0	0	
Magnesium	ppm	ASTM D5185(m)		<1	1	
Calcium	ppm	ASTM D5185(m)		<1	0	
Phosphorus	ppm	ASTM D5185(m)	280	288	295	
Zinc	ppm	ASTM D5185(m)	0.0	1	2	
Sulfur	ppm	ASTM D5185(m)		745	942	
Lithium	ppm	ASTM D5185(m)		0	<1	
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		0	<1	
Sodium	ppm	ASTM D5185(m)		0	0	
Potassium	ppm	ASTM D5185(m)	>20	0	2	
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*		0		
Nitration	Abs/cm	ASTM D7624*		2.2		
Sulfation	Abs/.1mm	ASTM D7415*		12.9		



OIL ANALYSIS REPORT



	INESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	925		
Particles >6µm		ASTM D7647	>1300	116		
Particles >14µm		ASTM D7647	>160	8		
Particles >21µm		ASTM D7647	>40	1		
Particles >38µm		ASTM D7647	>10	0		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>19/17/14	17/14/10		
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414*		2.2		
Acid Number (AN)	mg KOH/g	ASTM D974*	0.18	0.115	0.12	
Anti-Oxidant 1	%	ASTM D6971*	<25	100	100	
Anti-Oxidant 2	%	ASTM D6971*	<25	100	97	
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	
Precipitate	scalar	Visual*	NONE	NONE	NONE	
Silt		Visual*	NONE	NONE	NONE	
Debris	scalar	Visual*	NONE	NONE	NONE	
Sand/Dirt		Visual*	NONE	NONE	NONE	
Appearance	scalar	Visual*	NORML	NORML	NORML	
Odor	scalar	Visual*	NORML	NORML	NORML	
Emulsified Water	scalar	Visual*	INOTTIVIL	NEG	NEG	
Free Water		Visual*		NEG	NEG	
FLUID PROPER		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	34.15	33.7	34.3	
Visc @ 40 C	cSt	ASTM D7279(III) ASTM D7279(m)	5.60	5.6	5.6	
Viscosity Index (VI)	Scale	ASTM D7279(III) ASTM D2270*	100	103	100	
SAMPLE IMAG	ES	method	limit/base	current	history1	history2
Color						no image
						no image



CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No.

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : PC Lab Number : 02291243

Unique Number : 4886509

Received : 14 Jun 2019 **Tested** Diagnosed

: 19 Jun 2019

: 19 Jun 2019 - Kevin Marson Test Package : MAR 2 (Additional Tests: FT-IR, KV100, PrtCount, RULer, TAN Man, VI)

CA A1C 1B6 Contact: Josh Hynes joshynes@suncor.com T: (709)778-3575

Suncor - Terra Nova Projects

Scotia Centre, 235 Water Strret

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

St. John's, NL

F: (709)724-2835