

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id JENBACHER 1351185 Component

Natural Gas Engine

Fluid PETRO CANADA SENTRON CG 40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The condition of the oil is acceptable for the time in service.

SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC0045721		
Sample Date		Client Info		07 Jun 2022		
Machine Age	hrs	Client Info		27101		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>50	1		
Chromium	ppm	ASTM D5185(m)	>4	0		
Nickel	ppm	ASTM D5185(m)	>2	0		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)	>3	0		
Aluminum	ppm	ASTM D5185(m)	>9	1		
Lead	ppm	ASTM D5185(m)	>30	0		
Copper	ppm	ASTM D5185(m)	>35	0		
Tin	ppm	ASTM D5185(m)	>4	0		
Antimony	ppm	ASTM D5185(m)		<1		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	3		
Barium	ppm	ASTM D5185(m)	1	0		
Molybdenum	ppm	ASTM D5185(m)	2	1		
Manganese	ppm	ASTM D5185(m)	1	<1		
Magnesium	ppm	ASTM D5185(m)	9	17		
Calcium	ppm	ASTM D5185(m)	2712	2759		
Phosphorus	ppm	ASTM D5185(m)	292	244		
Zinc	ppm	ASTM D5185(m)	342	290		
Sulfur	ppm	ASTM D5185(m)	2575	2512		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>+100	7		
Sodium	ppm	ASTM D5185(m)		<1		
Potassium	ppm	ASTM D5185(m)	>20	<1		
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*		0		
Nitration	Abs/cm	ASTM D7624*	>20	3.2		
Sulfation	Abs/.1mm	ASTM D7415*	>30	12.6		
FLUID DEGRA	DATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414*	>25	7.2		
VISUAL		method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.1	NEG		
Free Water	scalar	Visual*		NEG		
1:15:03) Rev: 1				Contact/Location: Yvon Richard - CHAALL		

Contact/Location: Yvon Richard - CHAALL



OIL ANALYSIS REPORT





 Accredited Laboratory
 Unique Number
 : 5435305
 Diagnostician
 : Wes Davis

 Test Package
 : MOB 1 (Additional Tests: KV40, VI)

 To discuss this sample report, contact Customer Service at 1-800-268-2131.

 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

 Validity of results and interpretation are based on the sample and information as supplied.

 1300 RTE 360 ALLARDVILLE, NB CA E8L 1H5 Contact: Yvon Richard yvon.richard@csrchaleurrsc.ca T: (506)725-2402 F:



CALA

ISO 17025:2017

١Ē

Contact/Location: Yvon Richard - CHAALL