

Machine Id
REINTJES CAL012 (S/N K84269)

Component
Reduction Gear
Fluid
Mobilgear 600 XP 150 (600 LTR)

DIAGNOSIS

Recommendation

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			PC0011791	PC0052748	---
Sample Date	Client Info			03 Oct 2022	18 May 2022	---
Machine Age	hrs	Client Info		16509	0	---
Oil Age	hrs	Client Info		16509	0	---
Oil Changed		Client Info		Not Changed	Not Changed	---
Sample Status				NORMAL	NORMAL	---




CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>0.1	NEG	NEG	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>150	7	6	---
Chromium	ppm	ASTM D5185(m)	>10	0	0	---
Nickel	ppm	ASTM D5185(m)	>10	<1	0	---
Titanium	ppm	ASTM D5185(m)		0	0	---
Silver	ppm	ASTM D5185(m)		0	0	---
Aluminum	ppm	ASTM D5185(m)	>25	<1	0	---
Lead	ppm	ASTM D5185(m)	>100	3	2	---
Copper	ppm	ASTM D5185(m)	>50	10	7	---
Tin	ppm	ASTM D5185(m)	>10	1	1	---
Antimony	ppm	ASTM D5185(m)	>5	0	<1	---
Vanadium	ppm	ASTM D5185(m)		0	0	---
Beryllium	ppm	ASTM D5185(m)		0	0	---
Cadmium	ppm	ASTM D5185(m)		0	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		17	11	---
Barium	ppm	ASTM D5185(m)		0	0	---
Molybdenum	ppm	ASTM D5185(m)		0	0	---
Manganese	ppm	ASTM D5185(m)		<1	<1	---
Magnesium	ppm	ASTM D5185(m)		9	8	---
Calcium	ppm	ASTM D5185(m)		39	35	---
Phosphorus	ppm	ASTM D5185(m)		358	318	---
Zinc	ppm	ASTM D5185(m)		27	23	---
Sulfur	ppm	ASTM D5185(m)		10023	9605	---
Lithium	ppm	ASTM D5185(m)		<1	<1	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>50	0	<1	---
Sodium	ppm	ASTM D5185(m)		2	1	---
Potassium	ppm	ASTM D5185(m)	>20	<1	<1	---

OIL ANALYSIS REPORT




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	---
Emulsified Water	scalar	Visual*	>0.1	NEG	---
Free Water	scalar	Visual*		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	150	145	144
Visc @ 100°C	cSt	ASTM D7279(m)	15.8	14.3	14.2
Viscosity Index (VI)	Scale	ASTM D2270*	98	95	95

SAMPLE IMAGES

method	limit/base	current	history1	history2
Color				
Bottom				

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **Ocean Choice International - MV Calvert**
Sample No. : PC0011791 **Recieved** : 10 Jan 2023 1315 Topsail Rd, P.O. Box 8190
Lab Number : 02532363 **Diagnosed** : 10 Jan 2023 St. John's, NL
Unique Number : 5513362 **Diagnostician** : Wes Davis CA A1B 3N4
Test Package : MOB 1 (Additional Tests: KV100, VI)
 Contact: Calvert Engine Control Room
 calvertengine@oceanchoice.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.