

PROBLEM SUMMARY

Sample Rating Trend

VISUAL METAL



Area
1311
Machine Id


ROCK BREAKER HYDRAULIC POWER UNIT

Component

Hydraulic Power Pack

PETRO CANADA HYDREX XV ALL SEASON HYDRAULIC OIL (200 LTR)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation. We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. DISCLAIMER: Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified.

Check seals and/or filters for points of contaminant

| PROBLEMATIC TEST RESULTS | | | | | | | |
|--------------------------|--------|--------------|-----------|-----------------|------------------|---------------|--|
| Sample Status | | | | SEVERE | SEVERE | SEVERE | |
| Particles >4µm | | ASTM D7647 | >5000 | 63837 | 119043 | 69627 | |
| Particles >6µm | | ASTM D7647 | >1300 | △ 6548 | 30130 | △ 9567 | |
| Particles >14µm | | ASTM D7647 | >160 | <u> </u> | <u>1290</u> | <u></u> 181 | |
| Oil Cleanliness | | ISO 4406 (c) | >19/17/14 | 23/20/15 | 2 4/22/17 | 23/20/15 | |
| White Metal | scalar | Visual* | NONE | ▲ VLITE | NONE | NONE | |
| Debris | scalar | Visual* | NONE | ▲ LIGHT | NONE | VLITE | |
| PrtFilter | | | | - | no image | no image | |

Customer Id: INCVOS Sample No.: PC0040345 Lab Number: 02542930 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

| RECOMMENDED ACTIONS | | | | | | | |
|---------------------|--------|-------------|---------|---|--|--|--|
| Action | Status | Date | Done By | Description | | | |
| Change Filter | MISSED | Jun 06 2023 | ? | We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. | | | |
| Resample | MISSED | Jun 06 2023 | ? | Resample in 30-45 days to monitor this situation. | | | |
| Alert | MISSED | Jun 06 2023 | ? | We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. DISCLAIMER: Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified. | | | |
| Check Breathers | MISSED | Jun 06 2023 | ? | The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. | | | |
| Check Dirt Access | MISSED | Jun 06 2023 | ? | We advise that you check all areas where contaminants can enter the system. | | | |
| Check Seals | MISSED | Jun 06 2023 | ? | Check seals and/or filters for points of contaminant entry. | | | |
| Filter Fluid | MISSED | Jun 06 2023 | ? | We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. | | | |

HISTORICAL DIAGNOSIS

12 Jul 2022 Diag: Wes Davis

ISO



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6 μ m are severely high. Particles >4 μ m are severely high. Oil Cleanliness are severely high. Particles >14 μ m are abnormally high. Particles >21 μ m are abnormally high. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



09 Oct 2021 Diag: Wes Davis

ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >4 μ m are severely high. Particles >6 μ m are abnormally high. Particles >14 μ m are notably high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



03 Feb 2021 Diag: Wes Davis

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

Client Info

PC0040345

PC0040227

SAMPLE INFORMATION method

Sample Number

VISUAL METAL

PC0006177

history

<1

<1

Area 1311

ROCK BREAKER HYDRAULIC POWER UNIT

Hydraulic Power Pack

PETRO CANADA HYDREX XV ALL SEASON HYDRAULIC OIL (200 LTR)

DIAGNOSIS

Recommendation

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation. We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. DISCLAIMER: Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified.

Light concentration of visible metal present.


Contamination

Oil Cleanliness are severely high. Particles >4µm are severely high. Particles >6µm are abnormally high. Particles >6µm are abnormally high.. Particles >14µm are notably high. Light concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

| Campic Hamber | | Onone mile | | . 000 .00 .0 | 1 000 10227 | 1 00000177 |
|---------------|-----|---------------|------------|--------------|-------------|-------------|
| Sample Date | | Client Info | | 08 Feb 2023 | 12 Jul 2022 | 09 Oct 2021 |
| Machine Age | yrs | Client Info | | 0 | 0 | 0 |
| Oil Age | yrs | Client Info | | 0 | 0 | 0 |
| Oil Changed | | Client Info | | N/A | N/A | N/A |
| Sample Status | | | | SEVERE | SEVERE | SEVERE |
| WEAR METAL | _S | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185(m) | >20 | 7 | 5 | 2 |
| Chromium | ppm | ASTM D5185(m) | >20 | <1 | 0 | 0 |
| Nickel | ppm | ASTM D5185(m) | >20 | <1 | <1 | <1 |
| Titanium | ppm | ASTM D5185(m) | | <1 | <1 | 0 |
| Silver | ppm | ASTM D5185(m) | | 0 | 0 | <1 |
| Aluminum | ppm | ASTM D5185(m) | >20 | 1 | <1 | <1 |
| Lead | ppm | ASTM D5185(m) | >20 | <1 | <1 | 0 |
| Copper | ppm | ASTM D5185(m) | >20 | 3 | 4 | 2 |
| Tin | ppm | ASTM D5185(m) | >20 | 0 | 0 | 0 |
| Antimony | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Vanadium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Beryllium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185(m) | 0 | <1 | <1 | <1 |
| Barium | ppm | ASTM D5185(m) | 0 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185(m) | 0 | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185(m) | 1 | 0 | 0 | 0 |
| Magnesium | ppm | ASTM D5185(m) | 0 | <1 | 1 | <1 |
| Calcium | ppm | ASTM D5185(m) | 100 | 102 | 103 | 105 |
| Phosphorus | ppm | ASTM D5185(m) | 670 | 649 | 604 | 654 |
| Zinc | ppm | ASTM D5185(m) | 850 | 747 | 796 | 807 |
| Sulfur | ppm | ASTM D5185(m) | 1600 | 1511 | 1528 | 1458 |
| Lithium | ppm | ASTM D5185(m) | | <1 | <1 | <1 |
| CONTANTAL | | | | | | |



| Potassium | ppm | ASTM D5185(m) | >20 | <1 | <1 | <1 |
|-----------------|-------|---------------|------------|-----------------|------------------|---------------|
| FLUID CLEANL | INESS | method | limit/base | current | history1 | history2 |
| Particles >4µm | | ASTM D7647 | >5000 | 63837 | 119043 | 69627 |
| Particles >6µm | | ASTM D7647 | >1300 | 6548 | 30130 | △ 9567 |
| Particles >14µm | | ASTM D7647 | >160 | <u> </u> | <u> </u> | <u> </u> |
| Particles >21µm | | ASTM D7647 | >40 | 43 | <u> 171</u> | 20 |
| Particles >38µm | | ASTM D7647 | >10 | 1 | 3 | 0 |
| Particles >71µm | | ASTM D7647 | >3 | 0 | 1 | 0 |
| Oil Cleanliness | | ISO 4406 (c) | >19/17/14 | 23/20/15 | 2 4/22/17 | 23/20/15 |
| FLUID DEGRAD | OITAC | method | limit/base | current | history1 | history2 |

2

<1

Acid Number (AN)

CONTAMINANTS

Silicon

Sodium

mg KOH/g ASTM D974* 0.60

method

ASTM D5185(m)

ASTM D5185(m)

>15

ppm

ppm

Contact/Location: Robert Feltham - INCVOS

0.86


2

<1

0.75



OIL ANALYSIS REPORT



Validity of results and interpretation are based on the sample and information as supplied.

F: x: