


# **FUEL REPORT**

[450110686]

Emergency Generator - Diesel Fuel (S/N Sample Tag CD-84001)

**Diesel Fuel** 

No.2 DIESEL FUEL (HIGH-SULPHUR) (--- L





## DIAGNOSIS

### Recommendation

Laboratory test indicate that this fuel is suitable for use and meets all test requirements. Resample at the next service interval to monitor.

#### Corrosion

{not applicable}

## Contaminants

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. There is no indication of any contamination in the diesel fuel.


### **Fuel Condition**

All laboratory tests indicate that this sample meets specifications for No.2 diesel fuel, low sulfur (US EPA/CGSB-3.517-3 type B).

.TR)				Mar2023		
SAMPLE INFORM	/ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC0052226		
Sample Date		Client Info		01 Mar 2023		
Machine Age	hrs	Client Info		0		
Sample Status	1110			NORMAL		
PHYSICAL PROP	FRTIES	method	limit/base	current	history1	history2
	LITTILO	ASTM D1298*	0.839	0.847	•	,
Specific Gravity Fuel Color	tovt	Visual Screen*				
Visc @ 40°C	text cSt	ASTM D7279(m)	Yllow 3.0	Yllow 3		
Pensky-Martens Flash Point	°C	ASTM D7279(III) ASTM D7215*	52	64.6		
SULFUR CONT	ENI	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	500	171		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	176		
5% Distillation Point	°C	ASTM D2887*		201		
10% Distill Point	°C	ASTM D2887*	201	212		
15% Distillation Point	°C	ASTM D2887*		221		
20% Distill Point	°C	ASTM D2887*	216	230		
30% Distill Point	°C	ASTM D2887*	230	246		
40% Distill Point	°C	ASTM D2887*	243	260		
50% Distill Point	°C	ASTM D2887*	255	275		
60% Distill Point	°C	ASTM D2887*	267	290		
70% Distill Point	°C	ASTM D2887*	280	306		
80% Distill Point	°C	ASTM D2887*	295	323		
85% Distillation Point	°C	ASTM D2887*		337		
90% Distill Point	°C	ASTM D2887*	310	351		
95% Distillation Point	°C	ASTM D2887*		376		
Final Boiling Point	°C	ASTM D2887*	341	396		
IGNITION QUA	LITY	method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	35		
Cetane Index		ASTM D4737*	<40.0	49		
CONTAMINAN <sup>*</sup>	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	0		
Sodium	ppm	ASTM D5185(m)	<0.1	0		
Potassium	ppm	ASTM D5185(m)	<0.1	0		
Water	%	ASTM D6304*	< 0.05	0.001		
ppm Water	ppm	ASTM D6304*	<500	11.5		
FLUID CLEANL	.INESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	1063		
Particles >6µm		ASTM D7647	>640	241		
Particles >14µm		ASTM D7647	>80	25		
Particles >21μm		ASTM D7647	>20	8		
Particles >38μm		ASTM D7647	>4	1		
Particles >71μm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>18/16/13	17/15/12		



## **FUEL REPORT**





CALA ISO 17025:2017 Accredited

Laboratory Sample No. Lab Number **Unique Number** 

: PC0052226 : 02545898

: 5550908

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Received

Diagnosed : 21 Mar 2023 Diagnostician : Bill Quesnel

: 16 Mar 2023

Test Package : FUEL ( Additional Tests: CC Flash, GC-PercFuel, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

**Suncor - Terra Nova Projects** Scotia Centre, 235 Water Strret St. John's, NL

> CA A1C 1B6 Contact: Josh Hynes joshynes@suncor.com

T: (709)778-3575 F: (709)724-2835