


# PROBLEM SUMMARY

Area  
**1480**  
Machine Id  
**1480-5433-4009 - INSTRUMENT AIR COMPRESSOR**  
Component  
**Air Compressor**  
Fluid  
**INGERSOLL-RAND SSR ULTRA COOLANT (87 LTR)**

Sample Rating Trend




**OFF SPEC**



## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	SEVERE	SEVERE
Particles >4µm	ASTM D7647	>10000	▲ 24065	● 224044	● 369816
Particles >6µm	ASTM D7647	>2500	▲ 6688	● 67539	● 144162
Particles >14µm	ASTM D7647	>320	▲ 394	● 2836	● 4430
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 22/20/16	● 25/23/19	● 26/24/19
Viscosity Index (VI)	Scale	ASTM D2270*	▲ 261	91	148

Customer Id: INCVOS  
Sample No.: PC0040300  
Lab Number: 02548033  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.

## HISTORICAL DIAGNOSIS

### WATER



#### 24 Jun 2021 Diag: Kevin Marson

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Water and ppm water contamination levels are severe. Particles >14µm are severely high. Particles >6µm are severely high. Particles >4µm are severely high. Particles >21µm are abnormally high. There is a high concentration of water present in the oil. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid.

view report



### ISO



#### 20 Dec 2020 Diag: Wes Davis

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >14µm are severely high. Particles >21µm are severely high. Particles >6µm are severely high. Particles >4µm are severely high. Particles >38µm are abnormally high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### ISO




#### 03 Dec 2018 Diag: Wes Davis

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6µm are severely high. Particles >4µm are severely high. Particles >14µm are abnormally high. Particles >21µm are notably high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Area  
**1480**  
Machine Id  
**1480-5433-4009 - INSTRUMENT AIR COMPRESSOR**  
Component  
**Air Compressor**  
Fluid  
**INGERSOLL-RAND SSR ULTRA COOLANT (87 LTR)**



**DIAGNOSIS**

**Recommendation**

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

**Wear**

All component wear rates are normal.

**Contamination**

Oil Cleanliness are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high. Particles >14µm are notably high. The water content is negligible.

**Fluid Condition**

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

**SAMPLE INFORMATION**

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PC0040300</b>	PC0030078	PC0006132
Sample Date	Client Info	<b>11 Mar 2023</b>	24 Jun 2021	20 Dec 2020
Machine Age	yrs Client Info	<b>0</b>	0	0
Oil Age	yrs Client Info	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	SEVERE	SEVERE

**WEAR METALS**

method	limit/base	current	history1	history2
PQ	ASTM D8184*	<b>0</b>	0	0
Iron	ppm ASTM D5185(m) >70	<b>1</b>	2	8
Chromium	ppm ASTM D5185(m) >15	<b>0</b>	0	0
Nickel	ppm ASTM D5185(m) >6	<b>0</b>	0	<1
Titanium	ppm ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm ASTM D5185(m)	<b>0</b>	<1	<1
Aluminum	ppm ASTM D5185(m) >10	<b>&lt;1</b>	<1	<1
Lead	ppm ASTM D5185(m) >20	<b>&lt;1</b>	1	3
Copper	ppm ASTM D5185(m) >80	<b>1</b>	1	8
Tin	ppm ASTM D5185(m) >15	<b>0</b>	<1	0
Antimony	ppm ASTM D5185(m)	<b>0</b>	0	0
Vanadium	ppm ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm ASTM D5185(m)	<b>0</b>	0	0

**ADDITIVES**

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m) 0	<b>&lt;1</b>	▲ 25	2
Barium	ppm ASTM D5185(m) 500	<b>995</b>	596	884
Molybdenum	ppm ASTM D5185(m) 0	<b>0</b>	<1	0
Manganese	ppm ASTM D5185(m)	<b>0</b>	0	<1
Magnesium	ppm ASTM D5185(m) 0	<b>&lt;1</b>	<1	<1
Calcium	ppm ASTM D5185(m) 0	<b>1</b>	5	6
Phosphorus	ppm ASTM D5185(m) 20	<b>0</b>	<1	<1
Zinc	ppm ASTM D5185(m) 0	<b>9</b>	3	12
Sulfur	ppm ASTM D5185(m) 200	<b>380</b>	279	360
Lithium	ppm ASTM D5185(m)	<b>&lt;1</b>	<1	<1






**CONTAMINANTS**

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m) >12	<b>2</b>	5	3
Sodium	ppm ASTM D5185(m)	<b>19</b>	10	22
Potassium	ppm ASTM D5185(m) >20	<b>1</b>	2	2
Water	% ASTM D6304* >0.1	<b>0.095</b>	4.404	---
ppm Water	ppm ASTM D6304* >1000	<b>952.5</b>	44044.9	---

**FLUID CLEANLINESS**

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	▲ <b>24065</b>	224044	369816
Particles >6µm	ASTM D7647 >2500	▲ <b>6688</b>	67539	144162
Particles >14µm	ASTM D7647 >320	▲ <b>394</b>	2836	4430
Particles >21µm	ASTM D7647 >80	<b>72</b>	▲ 612	862
Particles >38µm	ASTM D7647 >20	<b>1</b>	26	▲ 53
Particles >71µm	ASTM D7647 >4	<b>0</b>	0	5
Oil Cleanliness	ISO 4406 (c) >20/18/15	▲ <b>22/20/16</b>	25/23/19	26/24/19

# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		<b>0.12</b>	0.09	0.09

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>VLITE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	LIGHT	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	LIGHT	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	LTMOD
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	<b>NEG</b>	▲ 1%	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	49.4	<b>35.5</b>	55.8	53.4
Visc @ 100°C	cSt	ASTM D7279(m)		<b>9.3</b>	7.4	9.0
Viscosity Index (VI)	Scale	ASTM D2270*	161	▲ <b>261</b>	91	148

## SAMPLE IMAGES



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0040300 **Received** : 28 Mar 2023  
**Lab Number** : **02548033** **Diagnosed** : 29 Mar 2023  
**Unique Number** : 5553043 **Diagnostician** : Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**Vale - Voisey's Bay**  
 Voisey's Bay Mine Site, P.O. Box 7001, Str. C Happy Valley  
 Goose Bay, NL  
 CA A0P 1C0  
 Contact: Robert Feltham  
 robert.feltham@vale.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.