

PROBLEM SUMMARY

Sample Rating Trend

VISCOSITY


158062 - BLEACH CHILLER 1


Component

Refrigeration Compressor

NU-CALGON C-3 (RO15)ISO 32 (--- GAL)

COMPONENT CONDITION SUMMARY





RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS													
Sample Status				ABNORMAL									
Visc @ 40°C	cSt	ASTM D7279(m)	33.0	24.7									
Visc @ 100°C	cSt	ΔSTM D7279(m)	4 36	A 6.4									

Customer Id: CANDRY Sample No.: PC0070208 Lab Number: 02554646 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT

Sample Rating Trend

VISCOSITY

Machine Id

158062 - BLEACH CHILLER 1

Component

Refrigeration Compressor

NU-CALGON C-3 (RO15)ISO 32 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition

The oil viscosity is lower than typical, possibly indicating the addition of lighter grade oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Apr2023		
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC0070208		
Sample Date		Client Info		26 Apr 2023		
Machine Age	yrs	Client Info		2		
Oil Age	yrs	Client Info		2		
Oil Changed		Client Info		Changed		
Sample Status				ABNORMAL		
WEAR METAL	S	method	limit/base	current	history1	history2
PQ		ASTM D8184*		0		
Iron	ppm	ASTM D5185(m)	>50	<1		
Chromium	ppm	ASTM D5185(m)	>10	0		
Nickel	ppm	ASTM D5185(m)		0		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)		0		
Aluminum	ppm	ASTM D5185(m)	>10	0		
Lead	ppm	ASTM D5185(m)	>10	0		
Copper	ppm	ASTM D5185(m)	>50	2		
Tin	ppm	ASTM D5185(m)	>10	0		
Antimony	ppm	ASTM D5185(m)		<1		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		<1		
Barium	ppm	ASTM D5185(m)		0		
Molybdenum	ppm	ASTM D5185(m)		0		
Manganese	ppm	ASTM D5185(m)		0		
Magnesium	ppm	ASTM D5185(m)		0		
Calcium	ppm	ASTM D5185(m)		0		
Phosphorus	ppm	ASTM D5185(m)		0		
Zinc	ppm	ASTM D5185(m)		2		
Sulfur	ppm	ASTM D5185(m)	200	158		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	1		
Sodium	ppm	ASTM D5185(m)		0		
Potassium	ppm	ASTM D5185(m)	>20	0		
Water	%	ASTM D6304*	>.0025	0.001		
ppm Water	ppm	ASTM D6304*	>25	8.2		
FLUID DEGRAD	OATION	method	limit/base	current	history1	history2


Acid Number (AN)

mg KOH/g ASTM D974* 0.014

0.02



OIL ANALYSIS REPORT





ISO 17025:2017 Accredited

Laboratory

Sample No. Lab Number **Unique Number**

: PC0070208

. 02554646

Diagnosed

: 03 May 2023 Diagnostician : Kevin Marson

: 5567661 Test Package : IND 2 (Additional Tests: KV100, TAN Man, VI) To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Box 3001, 1 Duke Street Dryden, ON **CA P8N 2Z7**

Contact: Yvon St. Laurent yvon.stlaurent@domtar.com T: (807)223-9838

F: (807)223-9176