


# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Machine Id  
**DRYER NH3 #3 (S/N 18029)**  
Component  
**Compressor**  
Fluid  
**TRIBOSPEC FRIGOSPEC ISO 68 (16 LTR)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

The water content is negligible. There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>PC0076117</b>	PC0058459	---
Sample Date	Client Info			<b>05 May 2023</b>	04 May 2022	---
Machine Age	hrs	Client Info		<b>0</b>	0	---
Oil Age	hrs	Client Info		<b>0</b>	0	---
Oil Changed	Client Info			<b>N/A</b>	N/A	---
Sample Status				<b>NORMAL</b>	NORMAL	---





WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*		<b>0</b>	0	---
Iron	ppm	ASTM D5185(m)	>50	<b>&lt;1</b>	2	---
Chromium	ppm	ASTM D5185(m)	>10	<b>0</b>	<1	---
Nickel	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	---
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	---
Silver	ppm	ASTM D5185(m)		<b>0</b>	<1	---
Aluminum	ppm	ASTM D5185(m)	>25	<b>0</b>	<1	---
Lead	ppm	ASTM D5185(m)	>25	<b>0</b>	0	---
Copper	ppm	ASTM D5185(m)	>50	<b>0</b>	1	---
Tin	ppm	ASTM D5185(m)	>15	<b>0</b>	<1	---
Antimony	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	---
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	---
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	---
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	---
Barium	ppm	ASTM D5185(m)		<b>0</b>	0	---
Molybdenum	ppm	ASTM D5185(m)		<b>0</b>	0	---
Manganese	ppm	ASTM D5185(m)		<b>0</b>	0	---
Magnesium	ppm	ASTM D5185(m)		<b>0</b>	0	---
Calcium	ppm	ASTM D5185(m)		<b>0</b>	0	---
Phosphorus	ppm	ASTM D5185(m)		<b>0</b>	0	---
Zinc	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	---
Sulfur	ppm	ASTM D5185(m)		<b>22</b>	23	---
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	<b>0</b>	0	---
Sodium	ppm	ASTM D5185(m)		<b>0</b>	0	---
Potassium	ppm	ASTM D5185(m)	>20	<b>0</b>	<1	---
Water	%	ASTM D6304*	>0.1	<b>0.00</b>	0.003	---
ppm Water	ppm	ASTM D6304*	>1000	<b>0.00</b>	29.7	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		<b>0.01</b>	0.02	---


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	---
Odor	scalar	Visual*	NORML	AMMON	---
Emulsified Water	scalar	Visual*	>0.1	NEG	---
Free Water	scalar	Visual*		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	63.8	69.3	67.9
Visc @ 100°C	cSt	ASTM D7279(m)	6.7	9	9
Viscosity Index (VI)	Scale	ASTM D2270*	103	106	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0076117 **Received** : 09 May 2023  
**Lab Number** : 02556209 **Diagnosed** : 10 May 2023  
**Unique Number** : 5577249 **Diagnostician** : Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, TAN MAN, VI )

**SAPUTO FOODS LTD**  
 284 HOPE STREET WEST  
 TAVISTOCK, ON  
 CA N0B 2R0  
 Contact: Joseph Ross  
 joseph.ross@saputo.com  
 T: (519)655-2337  
 F: (519)655-3449

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.