

OIL ANALYSIS REPORT

Sample Rating Trend



#1 CO2 COMP

Component Compressor Fluid REFRIG COMP OIL ISO 68 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) REFRIG COMP OIL ISO 68. Please confirm.

Wear

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


			Jun2022	May2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC0052463	PC0052848	
Sample Date		Client Info		15 May 2023	07 Jun 2022	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
WEAR METAL	S	method	limit/base	current	history1	history2
PQ		ASTM D8184*		0	0	
Iron	ppm	ASTM D5185(m)	>50	<1	<1	
Chromium	ppm	ASTM D5185(m)	>10	0	0	
Nickel	ppm	ASTM D5185(m)		0	0	
Titanium	ppm	ASTM D5185(m)		0	0	
Silver	ppm	ASTM D5185(m)		0	0	
Aluminum	ppm	ASTM D5185(m)	>25	0	<1	
Lead	ppm	ASTM D5185(m)	>25	0	<1	
Copper	ppm	ASTM D5185(m)	>50	<1	2	
Tin	ppm	ASTM D5185(m)	>15	0	<1	
Antimony	ppm	ASTM D5185(m)		0	0	
Vanadium	ppm	ASTM D5185(m)		0	0	
Beryllium	ppm	ASTM D5185(m)		0	0	
Cadmium	ppm	ASTM D5185(m)		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	5	0	<1	
Barium	ppm	ASTM D5185(m)	5	0	0	
Molybdenum	ppm	ASTM D5185(m)	5	0	0	
Manganese	ppm	ASTM D5185(m)		0	0	
Magnesium	ppm	ASTM D5185(m)	5	0	0	
Calcium	ppm	ASTM D5185(m)	12	0	<1	
Phosphorus	ppm	ASTM D5185(m)	12	0	2	
Zinc	ppm	ASTM D5185(m)	12	<1	<1	
Sulfur	ppm	ASTM D5185(m)	1000	5	14	
Lithium	ppm	ASTM D5185(m)		<1	<1	
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	6	5	
Sodium	ppm	ASTM D5185(m)		0	0	
Potassium	ppm	ASTM D5185(m)	>20	0	<1	
Water	%	ASTM D6304*	>0.1	0.001	0.001	
ppm Water	ppm	ASTM D6304*	>1000	3.5	3.0	
FLUID DEGRAD	DAT <u>ION</u>	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.10	0.01	0.03	
. ,						




OIL ANALYSIS REPORT









: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Labatt - St. John's Brewery Received : PC0052463 : 16 May 2023 60 Leslie Street St John's, NL : 02557839 Diagnosed : 17 May 2023 : Wes Davis CA A1E 2V8 : 5578879 Diagnostician Laboratory Test Package : IND 2 (Additional Tests: KF, KV100, VI) Contact: Rod Penney ŵ To discuss this sample report, contact Customer Service at 1-800-268-2131. rod.penney@labatt.com Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: (709)570-7152 Validity of results and interpretation are based on the sample and information as supplied. F: (709)570-7160

Report Id: LABSTJ [WCAMIS] 02557839 (Generated: 08/23/2023 12:41:56) Rev: 1

Contact/Location: Rod Penney - LABSTJ