

Machine Id
C0029

Component
Compressor

Fluid
GARDNER DENVER AEON 9000 TH (--- GAL)

DIAGNOSIS

Recommendation

Échantillonner de nouveau l'équipement au prochain intervalle de vidange afin d'en surveiller la condition.

Wear

Les taux d'usure de tous les composants sont normaux.

Contamination

La teneur en eau est négligeable. Il n'y a aucun indice de contamination dans l'huile.

Fluid Condition

La viscosité de l'huile est plus élevée que la normale. Le AN est acceptable pour ce fluide. L'état de l'huile permet d'en prolonger l'utilisation.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PC0061974	PC0061980	PC0061750
Sample Date	Client Info		30 May 2023	11 Feb 2023	29 Dec 2022
Machine Age	hrs	Client Info	74806	73095	72546
Oil Age	hrs	Client Info	1700	8339	7790
Oil Changed	Client Info		Not Changed	Changed	Not Changed
Sample Status			NORMAL	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	0	0
Iron	ppm	ASTM D5185(m) >50	<1	2	2
Chromium	ppm	ASTM D5185(m) >5	0	0	0
Nickel	ppm	ASTM D5185(m)	0	0	0
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	0	0	0
Aluminum	ppm	ASTM D5185(m) >15	<1	<1	0
Lead	ppm	ASTM D5185(m) >65	0	<1	0
Copper	ppm	ASTM D5185(m) >65	0	1	0
Tin	ppm	ASTM D5185(m) >10	0	<1	0
Antimony	ppm	ASTM D5185(m)	<1	<1	<1
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<1	2	<1
Barium	ppm	ASTM D5185(m)	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0
Magnesium	ppm	ASTM D5185(m)	0	0	0
Calcium	ppm	ASTM D5185(m)	0	0	0
Phosphorus	ppm	ASTM D5185(m)	838	736	744
Zinc	ppm	ASTM D5185(m)	<1	1	<1
Sulfur	ppm	ASTM D5185(m)	5	4	7
Lithium	ppm	ASTM D5185(m)	<1	<1	<1






CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >35	0	<1	<1
Sodium	ppm	ASTM D5185(m)	<1	1	2
Potassium	ppm	ASTM D5185(m) >20	1	<1	0
Water	%	ASTM D6304* >0.1	0.032	0.023	0.028
ppm Water	ppm	ASTM D6304* >1000	327.8	234.6	282.8

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.38	0.75	0.87

OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	60.01	79.8	78.3
Visc @ 100°C	cSt	ASTM D7279(m)	8.6	10.8	11.9
Viscosity Index (VI)	Scale	ASTM D2270*	126	121	146

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0061974
Lab Number : 02561763
Unique Number : 5590804
Test Package : IND 2 (Additional Tests: KF, KV100, VI)

Received : 05 Jun 2023
Diagnosed : 06 Jun 2023
Diagnostician : Kevin Marson

ROUSSEAU METAL
 105 DE GASPE OUEST
 ST-JEAN PORT JOLI, QC
 CA G0R 3G0
 Contact: Sylvain Guay
 sylvain.guay@rousseau.com
 T:
 F: (418)598-6776

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.