


# PROBLEM SUMMARY


Area  
**CHIQUITA TROPICAL INGREDIENTS SA (MUNDIMAR)**  
Machine Id  
**HOWDEN COMPRESSOR HOWDEN 1PD (AF1180)**  
Component  
**Compressor**  
Fluid  
**PETRO CANADA REFLO 68A AMMONIA OIL (75 GAL)**

Sample Rating Trend



## COMPONENT CONDITION SUMMARY

Particle Trend



## RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

## PROBLEMATIC TEST RESULTS

Sample Status		SEVERE	SEVERE	SEVERE
Particles >4µm	ASTM D7647 >10000	93904	207154	127486
Particles >6µm	ASTM D7647 >2500	26074	146370	35276
Particles >14µm	ASTM D7647 >320	366	9934	304
Oil Cleanliness	ISO 4406 (c) >20/18/15	24/22/16	25/24/20	24/22/15

Customer Id: INDALA  
Sample No.: PC0077175  
Lab Number: 02562227  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Wes Davis +1 905-569-8600 x223  
[wesd@wearcheck.ca](mailto:wesd@wearcheck.ca)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.

## HISTORICAL DIAGNOSIS

### 29 Aug 2018 Diag: Kevin Marson

ISO



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. Iron ppm levels are marginal. All other component wear rates are normal. Particles >14µm are severely high. Particles >21µm are severely high. Particles >6µm are severely high. Particles >4µm are severely high. The AN level is acceptable for this fluid. The water concentration level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 03 May 2018 Diag: Bill Quesnel

ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6µm are severely high. Particles >4µm are severely high. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 10 Nov 2017 Diag: Bill Quesnel

ISO




Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6µm are severely high. Particles >4µm are severely high. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



Area  
**CHIQUITA TROPICAL INGREDIENTS SA (MUNDIMAR)**  
Machine Id  
**HOWDEN COMPRESSOR HOWDEN 1PD (AF1180)**  
Component  
**Compressor**  
Fluid  
**PETRO CANADA REFLO 68A AMMONIA OIL (75 GAL)**



**DIAGNOSIS**

**Recommendation**

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

**Wear**

All component wear rates are normal.

**Contamination**

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

**Fluid Condition**

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

**SAMPLE INFORMATION**

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PC0077175</b>	PC410516	PC409189
Sample Date	Client Info	<b>25 May 2023</b>	29 Aug 2018	03 May 2018
Machine Age	hrs	<b>0</b>	42030	40961
Oil Age	hrs	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	Not Changd	Not Changd
Sample Status		<b>SEVERE</b>	SEVERE	SEVERE

**WEAR METALS**

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185(m) >50	<b>7</b>	▲ 34	7
Chromium	ppm ASTM D5185(m) >10	<b>0</b>	0	0
Nickel	ppm ASTM D5185(m)	<b>0</b>	0	0
Titanium	ppm ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm ASTM D5185(m)	<b>0</b>	0	<1
Aluminum	ppm ASTM D5185(m) >25	<b>&lt;1</b>	0	0
Lead	ppm ASTM D5185(m) >25	<b>0</b>	2	<1
Copper	ppm ASTM D5185(m) >50	<b>0</b>	0	<1
Tin	ppm ASTM D5185(m) >15	<b>0</b>	0	0
Antimony	ppm ASTM D5185(m)	<b>0</b>	0	0
Vanadium	ppm ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm ASTM D5185(m)	<b>0</b>	<1	0

**ADDITIVES**

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m) 0	<b>&lt;1</b>	0	0
Barium	ppm ASTM D5185(m) 0	<b>0</b>	0	0
Molybdenum	ppm ASTM D5185(m) 0	<b>0</b>	0	0
Manganese	ppm ASTM D5185(m)	<b>0</b>	<1	0
Magnesium	ppm ASTM D5185(m) 0	<b>&lt;1</b>	<1	0
Calcium	ppm ASTM D5185(m) 0	<b>0</b>	<1	0
Phosphorus	ppm ASTM D5185(m) 0	<b>0</b>	<1	<1
Zinc	ppm ASTM D5185(m) 0	<b>2</b>	2	1
Sulfur	ppm ASTM D5185(m) 0	<b>2</b>	0	4
Lithium	ppm ASTM D5185(m)	<b>&lt;1</b>	0	<1






**CONTAMINANTS**

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m) >25	<b>1</b>	4	<1
Sodium	ppm ASTM D5185(m)	<b>0</b>	0	0
Potassium	ppm ASTM D5185(m) >20	<b>0</b>	0	<1
Water	% ASTM D6304* >0.1	<b>0.00</b>	0.002	0.000
ppm Water	ppm ASTM D6304* >1000	<b>0.00</b>	28.1	3.4

**FLUID CLEANLINESS**

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	<b>93904</b>	207154	127486
Particles >6µm	ASTM D7647 >2500	<b>26074</b>	146370	35276
Particles >14µm	ASTM D7647 >320	<b>366</b>	9934	304
Particles >21µm	ASTM D7647 >80	<b>55</b>	697	35
Particles >38µm	ASTM D7647 >20	<b>1</b>	0	0
Particles >71µm	ASTM D7647 >4	<b>1</b>	0	0
Oil Cleanliness	ISO 4406 (c) >20/18/15	<b>24/22/16</b>	25/24/20	24/22/15

# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.05	<b>0.01</b>	0.042	0.021

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	VLITE	VLITE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	AMMON	AMMON
Emulsified Water	scalar	Visual*	>0.1	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	57.8	<b>59.1</b>	57.7	56.6
Visc @ 100°C	cSt	ASTM D7279(m)	7.86	<b>8.7</b>	8.7	8.4
Viscosity Index (VI)	Scale	ASTM D2270*	101	<b>121</b>	125	120

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **INDUSTRIAS del PETROLEO CANAD. SA**  
**Sample No.** : PC0077175 **Received** : 06 Jun 2023 Contiguo FANAL, frente a la Autopista Bernardo Soto  
**Lab Number** : **02562227** **Diagnosed** : 08 Jun 2023 Grecia, A  
**Unique Number** : 5591268 **Diagnostician** : Wes Davis CR  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, VI )  
 To discuss this sample report, contact Customer Service at 1-800-268-2131. Contact: Erick Bogantes  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. cotizaciones@lubricantescanada.com  
 Validity of results and interpretation are based on the sample and information as supplied. T: 1(115)062-1598  
 F: 1(115)062-2870