

Machine Id  
**P2**

Component  
**Bearing**

Fluid  
**PETRO CANADA SYNDURO SHB ISO 220 (--- LTR)**

## DIAGNOSIS

### Recommendation

Échantillonner de nouveau l'équipement au prochain intervalle de vidange afin d'en surveiller la condition. À NOTER: S.V.P. inclure, avec le prochain échantillon, des détails de la capacité du réservoir et le type et le degré de filtration.

### Wear

Les taux d'usure de tous les composants sont normaux.

### Contamination

Il n'y a aucun indice de contamination dans l'huile.

### Fluid Condition

Le AN est acceptable pour ce fluide. L'état de l'huile permet d'en prolonger l'utilisation.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PC0076180</b>	PC0076175	PC0070509
Sample Date	Client Info		<b>13 Jun 2023</b>	30 May 2023	20 Feb 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>Changed</b>	N/A	N/A
Sample Status			<b>NORMAL</b>	NORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		<b>0</b>	0	0
Iron	ppm	ASTM D5185(m) >200	<b>2</b>	2	2
Chromium	ppm	ASTM D5185(m) >5	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m) >5	<b>&lt;1</b>	0	<1
Titanium	ppm	ASTM D5185(m) >5	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m) >25	<b>&lt;1</b>	<1	<1
Lead	ppm	ASTM D5185(m) >50	<b>&lt;1</b>	<1	<1
Copper	ppm	ASTM D5185(m) >150	<b>6</b>	5	6
Tin	ppm	ASTM D5185(m) >10	<b>31</b>	29	▲ 30
Antimony	ppm	ASTM D5185(m)	<b>2</b>	2	2
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<b>0</b>	<1	1
Barium	ppm	ASTM D5185(m) 5.0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m)	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185(m) 5.0	<b>0</b>	0	0
Calcium	ppm	ASTM D5185(m) 5.0	<b>0</b>	0	0
Phosphorus	ppm	ASTM D5185(m) 100	<b>105</b>	102	102
Zinc	ppm	ASTM D5185(m) 5.0	<b>6</b>	6	8
Sulfur	ppm	ASTM D5185(m) 1900	<b>2002</b>	1909	1922
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1






## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >25	<b>1</b>	<1	2
Sodium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Potassium	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	0	0

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974* 0.3	<b>0.33</b>	0.34	0.30

# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	219	217	218
Visc @ 100°C	cSt	ASTM D7279(m)	27.4	27.1	27.0
Viscosity Index (VI)	Scale	ASTM D2270*	160	159	158

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0076180 **Received** : 15 Jun 2023  
**Lab Number** : 02564548 **Diagnosed** : 16 Jun 2023  
**Unique Number** : 5593589 **Diagnostician** : Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: KV100, TAN Man, VI )

**WESDOME KIENA MINE**  
 950 CHEMIN KIENAWISIK  
 VAL-D'OR, QC  
 CA J0P 4P3  
 Contact: Michel Larose  
 michel.larose@wesdome.com  
 T:  
 F: (819)738-5452

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.