


OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id

G-21-23

Component

Reference Grease

Fluid

PETRO CANADA PEERLESS LLG (--- GAL)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample.

Wear

{not applicable}

Grease Condition

{not applicable}

Contaminants

{not applicable}

SAMPLE INFORMATION

| method | limit/base | current | history 1 | history 2 |
|-----------------|-----------------|--------------------|-----------|-----------|
| Sample Number | Client Info | PC | --- | --- |
| Sample Date | Client Info | 14 Jun 2023 | --- | --- |
| Machine Age | hrs Client Info | 0 | --- | --- |
| Grease Age | hrs Client Info | 0 | --- | --- |
| Grease Serviced | Client Info | N/A | --- | --- |
| Sample Status | | NORMAL | --- | --- |



FLUID DEGRADATION

| method | limit/base | current | history 1 | history 2 |
|----------------|-------------------|------------|-----------|-----------|
| Anti-Oxidant 1 | % ASTM D6971* <25 | 100 | --- | --- |
| Anti-Oxidant 2 | % ASTM D6971* <25 | 100 | --- | --- |


VISUAL

| method | limit/base | current | history 1 | history 2 |
|--------------|----------------------|--------------|-----------|-----------|
| White Metal | scalar Visual* NONE | NONE | --- | --- |
| Yellow Metal | scalar Visual* NONE | NONE | --- | --- |
| Precipitate | scalar Visual* NONE | NONE | --- | --- |
| Silt | scalar Visual* NONE | NONE | --- | --- |
| Debris | scalar Visual* NONE | NONE | --- | --- |
| Sand/Dirt | scalar Visual* NONE | NONE | --- | --- |
| Appearance | scalar Visual* NORML | NORML | --- | --- |
| Odor | scalar Visual* NORML | NORML | --- | --- |



SAMPLE IMAGES

| method | limit/base | current | history 1 | history 2 |
|--------|------------|---|-----------|-----------|
| Color | |  | no image | no image |
| Bottom | |  | no image | no image |

OIL ANALYSIS REPORT



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Petro-Canada Technical/Martin Keenan
Sample No. : PC **Received** : 15 Jun 2023
Lab Number : 02564576 **Diagnosed** : 30 Jun 2023
Unique Number : 5593617 **Diagnostician** : Bill Quesnel
Test Package : TEST (Additional Tests: RULer)

Mississauga, ON
CA L5J 1K2
Contact: Martin Keenan

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

T:
F: (905)403-6740