


PROBLEM SUMMARY

Sample Rating Trend




ISO



Machine Id
SUMITOMO PRESS #5 CROWN
Component
Gearbox
Fluid
ESSO SPARTAN EP 220 (200 LTR)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	SEVERE
Particles >4µm	ASTM D7647	>20000	▲ 104326	▲ 98043	● 217634
Particles >6µm	ASTM D7647	>5000	▲ 35043	▲ 19624	● 78534
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 24/22/16	▲ 24/21/16	● 25/23/17

Customer Id: VENSTC
Sample No.: PC0061353
Lab Number: 02566271
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Wes Davis +1 905-569-8600 x223
wesd@wearcheck.ca

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

05 Jul 2022 Diag: Wes Davis

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Oil Cleanliness are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



28 Mar 2019 Diag: Wes Davis

ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6µm are severely high. Particles >4µm are severely high. Particles >14µm are notably high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



12 Aug 2015 Diag: Wes Davis

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >4µm are abnormally high. Particles >6µm are abnormally high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





Machine Id
SUMITOMO PRESS #5 CROWN

Component
Gearbox
Fluid
ESSO SPARTAN EP 220 (200 LTR)



DIAGNOSIS

Recommendation
We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Wear
All component wear rates are normal.

Contamination
There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PC0061353	PC0010456	PC0005751
Sample Date	Client Info	22 Jun 2023	05 Jul 2022	28 Mar 2019
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	SEVERE

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m) >200	36	26	66
Chromium	ppm	ASTM D5185(m) >15	1	<1	2
Nickel	ppm	ASTM D5185(m) >15	0	<1	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	0	0	0
Aluminum	ppm	ASTM D5185(m) >25	<1	<1	<1
Lead	ppm	ASTM D5185(m) >100	1	2	1
Copper	ppm	ASTM D5185(m) >200	18	14	18
Tin	ppm	ASTM D5185(m) >25	1	<1	1
Antimony	ppm	ASTM D5185(m) >5	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	<1

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m) .5	28	41	28
Barium	ppm	ASTM D5185(m)	0	0	<1
Molybdenum	ppm	ASTM D5185(m) 0	0	0	0
Manganese	ppm	ASTM D5185(m)	<1	<1	<1
Magnesium	ppm	ASTM D5185(m) 0	<1	<1	<1
Calcium	ppm	ASTM D5185(m) 1.7	2	3	2
Phosphorus	ppm	ASTM D5185(m) 250	261	249	238
Zinc	ppm	ASTM D5185(m) .3	6	7	4
Sulfur	ppm	ASTM D5185(m)	8113	9895	8432
Lithium	ppm	ASTM D5185(m)	<1	<1	0

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m) >50	4	4	6
Sodium	ppm	ASTM D5185(m)	<1	1	<1
Potassium	ppm	ASTM D5185(m) >20	<1	0	0






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	▲ 104326	▲ 98043	● 217634
Particles >6µm	ASTM D7647 >5000	▲ 35043	▲ 19624	● 78534
Particles >14µm	ASTM D7647 >640	532	520	▲ 1157
Particles >21µm	ASTM D7647 >160	55	87	161
Particles >38µm	ASTM D7647 >40	17	10	0
Particles >71µm	ASTM D7647 >10	14	6	0
Oil Cleanliness	ISO 4406 (c) >21/19/16	▲ 24/22/16	▲ 24/21/16	● 25/23/17

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D974* 0.75	0.40	0.43	0.345


OIL ANALYSIS REPORT



PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	VLITE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	VLITE	NONE
Debris	scalar	Visual*	NONE	VLITE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

PARAMETER	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	220	221	219
Visc @ 100°C	cSt	ASTM D7279(m)	18.6	19.4	20.0
Viscosity Index (VI)	Scale	ASTM D2270*	93	99	105

PARAMETER	method	limit/base	current	history1	history2
Color					
Bottom					no image



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0061353
Lab Number : 02566271
Unique Number : 5603317
Test Package : IND 2 (Additional Tests: KV100, PrtCount, TAN Man, VI)

Received : 23 Jun 2023
Diagnosed : 26 Jun 2023
Diagnostician : Wes Davis

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Venest Industries Inc.
 2032 First Street Louth
 St. Catharines, ON
 CA L2S 0C5
 Contact: Allen Taylor
 allen.taylor@magna.com
 T: (905)401-9948
 F: