


PROBLEM SUMMARY

P4 PRESS 4 CROWN

Unknown Component



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend that you service/replace the breather. We recommend that you drain the sample from the component if this has not already been done. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please provide more complete information on your next sample.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	
Appearance	scalar	Visual*	NORML	🔺 LAYRD	
Emulsified Water	scalar	Visual*		.2%	
Free Water	scalar	Visual*		<u> >10%</u>	
Viscosity Index (VI)	Scale	ASTM D2270*	99	/ 73	

Sample Rating Trend

WATER

Customer Id: VENSTC Sample No.: PC0061349 Lab Number: 02566287 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Fluid			?	We recommend that you drain the sample from the component if this has not already been done.		
Resample			?	We recommend an early resample to monitor this condition.		
Information Required			?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please provide more complete information on your next sample.		
Check Breathers			?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.		
Check Fluid Source			?	Confirm the source of the lubricant being utilized for top-up/fill.		
Check Water Access			?	We advise that you check for the source of water entry.		
Check Seals			?	Check seals and/or filters for points of contaminant entry.		

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT

Sample Rating Trend

WATER

P4 PRESS 4 CROWN

Unknown Component

PETRO CANADA ENDURATEX EP 220 (--- LTR)

DIAGNOSIS

A Recommendation

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend that you drain the sample from the component if this has not already been done. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please provide more complete information on your next sample.

Wear

All component wear rates are normal.

Contamination

There is a moderate concentration of water present in the sample. Excessive free water present.


Fluid Condition


Additive levels indicate the addition of a different brand, or type of sample. The AN level is acceptable for this fluid. The sample is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


				Jun2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC0061349		
Sample Date		Client Info		22 Jun 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS	S	method	limit/base	current	history1	history2
PQ		ASTM D8184*		379		
Iron	ppm	ASTM D5185(m)		31		
Chromium	ppm	ASTM D5185(m)		<1		
Nickel	ppm	ASTM D5185(m)		<1		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)		<1		
Aluminum	ppm	ASTM D5185(m)		1		
Lead	ppm	ASTM D5185(m)		2		
Copper	ppm	ASTM D5185(m)		28		
Tin	ppm	ASTM D5185(m)		1		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	60	6		
Barium	ppm	ASTM D5185(m)	0	11		
Molybdenum	ppm	ASTM D5185(m)	0	0		
Manganese	ppm	ASTM D5185(m)	0	1		
Magnesium	ppm	ASTM D5185(m)	0	2		
Calcium	ppm	ASTM D5185(m)	0	4		
Phosphorus	ppm	ASTM D5185(m)	270	245		
Zinc	ppm	ASTM D5185(m)	0	44		
Sulfur	ppm	ASTM D5185(m)	11200	2948		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		3		
Sodium	ppm	ASTM D5185(m)		1		
Potassium	ppm	ASTM D5185(m)	>20	1		
FLUID DEGRAD	OATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.40	0.49		



OIL ANALYSIS REPORT







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE		
ellow Metal	scalar	Visual*	NONE	NONE		
Precipitate	scalar	Visual*	NONE	NONE		
Silt	scalar	Visual*	NONE	NONE		
Debris	scalar	Visual*	NONE	VLITE		
Sand/Dirt	scalar	Visual*	NONE	NONE		
Appearance	scalar	Visual*	NORML	🔺 LAYRD		
Odor	scalar	Visual*	NORML	NORML		
Emulsified Water	scalar	Visual*		.2%		
Free Water	scalar	Visual*	4	<mark> </mark> >10%		
FLUID PROPER	RTIES	method	limit/base	current	history1	history2
/isc @ 40°C	cSt	ASTM D7279(m)	220	207		
/isc @ 100°C	cSt	ASTM D7279(m)	19.35	15.9		
/iscosity Index (VI)	Scale	ASTM D2270*	99	<mark> </mark> 73		
SAMPLE IMAG	ES	method	limit/base	current	history1	history2
Color					no image	no image
					nomage	
ottom					no image	no image
GRAPHS	_					
Ferrous Alloys				PQ		
iron			400			
nickel			350	-		
			300			
. 2/23 .			. 250 2200 0,200			
Jun22/23			7un 200	Severe		
Non-ferrous Metals	5					
copper			150			
tin			100	Abnormal		
			50			
2/23			2/23	123		22
Jun22,			Jun22/23	Jun22/23		100000
Viscosity @ 40°C				Acid Number		
Abnormal			(P) 0.50 (P) 0.40 (E) 0.30 (E) 0.20 (P) 0.20 (P) 0.10	Base		
Base			⊻ 0.40 Ĕn 20	- 0		
Q		*****				
Abnormal			N 0.10			
/23						5
Jun22/23			Jun22/23	Jun22/23		20/20 mil
02566287 D 5603333 D	Received Diagnose Diagnost	i : 23 . ed : 26 .	Jun 2023 Jun 2023 in Marson	7L 5H9	2032 Fi St. (Industries Inc rst Street Lout Catharines, Of CA L2S 0C ct: Allen Taylo

Report Id: VENSTC [WCAMIS] 02566287 (Generated: 07/17/2023 09:43:44) Rev: 1

allen.taylor@magna.com

T: (905)401-9948

F: