

Area **1851** Machine Id **1851-5419-8002** Component **Gearbox** Fluid **NOT GIVEN (15 LTR)**

DIAGNOSTICS

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

PROBLEMATIC TES	T RESULT	S			
Sample Status			ATTENTION	ATTENTION	NORMAL
Particles >4µm	ASTM D7647	>20000	<u> </u>	2 5715	40453
Oil Cleanliness	ISO 4406 (c)	>21/19/16	A 22/19/14	A 22/19/14	23/20/15

Customer Id: INCVOS Sample No.: PC0040491 Lab Number: 02567632 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Wes Davis +1 905-569-8600 x223 wesd@wearcheck.ca

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 <u>gloria.gonzalez@wearcheck.com</u>



RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Filter			?	We recommend you service the filters on this component.			
Information Required			?	Please specify the brand, type, and viscosity of the oil on your next sample.			

HISTORICAL DIAGNOSIS



18 Apr 2023 Diag: Kevin Marson

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. Viscosity of sample indicates oil is within ISO 150 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report

26 Mar 2023 Diag: Kevin Marson





Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is no indication of any contamination in the oil. Viscosity of sample indicates oil is within ISO 150 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT



ISO



Fluid NOT GIVEN (15 LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	/IATION	method	limit/base	current	history 1	history 2
Sample Number		Client Info		PC0040491	PC0058645	PC0040296
Sample Date		Client Info		13 Jun 2023	18 Apr 2023	26 Mar 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	Not Changd
Sample Status				ATTENTION	ATTENTION	NORMAL
WEAR METALS	S	method	limit/base	current	history 1	history 2
PQ		ASTM D8184*		2	0	0
Iron	ppm	ASTM D5185(m)	>200	11	11	11
Chromium	ppm	ASTM D5185(m)	>15	0	0	0
Nickel	ppm	ASTM D5185(m)	>15	<1	<1	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>25	<1	<1	<1
Lead	ppm	ASTM D5185(m)	>100	0	0	0
Copper	ppm	ASTM D5185(m)	>200	<1	<1	<1
Tin	ppm	ASTM D5185(m)	>25	0	0	0
Antimony	ppm	ASTM D5185(m)	>5	0	<1	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185(m)		1	<1	<1
Barium	ppm	ASTM D5185(m)		0	0	0
Molybdenum	ppm	ASTM D5185(m)		0	0	0
Manganese	ppm	ASTM D5185(m)		<1	<1	<1
Magnesium	ppm	ASTM D5185(m)		<1	0	<1
Calcium	ppm	ASTM D5185(m)		<1	0	0
Phosphorus	ppm	ASTM D5185(m)		82	81	81
Zinc	ppm	ASTM D5185(m)		3	2	3
Sulfur	ppm	ASTM D5185(m)		1820	1826	1838
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
CONTAMINAN	TS	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185(m)	>50	10	12	12
Sodium	ppm	ASTM D5185(m)		<1	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	<1	12	0
FLUID CLEANL	INESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647	>20000	A 33689	A 25715	40453
Particles >6μm		ASTM D7647	>5000	3789	2981	5414
Particles >14µm		ASTM D7647	>640	95	105	296
Particles >21µm		ASTM D7647	>160	25	25	69
Particles >38µm		ASTM D7647	>40	3	1	7
Particles >71µm		ASTM D7647	>10	0	1	5
Oil Cleanliness		ISO 4406 (c)	>21/19/16	<u> </u>	2 2/19/14	23/20/15



🔺 Particle Count

491,520 122,880 Ê 30,720 7 68

> 1.920 480

> > 180 160 140

OIL ANALYSIS REPORT

FLUID DEGRAD	DATION	method	limit/base	current	history 1	history
Acid Number (AN)	mg KOH/g	ASTM D974*		0.34	0.32	0.35
VISUAL		method	limit/base	current	history 1	history
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	VLITE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG
FLUID PROPE	RTIES	method	limit/base	current	history 1	history
Visc @ 40°C	cSt	ASTM D7279(m)		146	146	146
Visc @ 100°C	cSt	ASTM D7279(m)		19.8	19.9	19.9
Viscosity Index (VI)	Scale	ASTM D2270*		156	157	157
SAMPLE IMAG	ES	method	limit/base	current	history 1	history
					le	
Color						
				Contraction of		
						
Bottom						UP



Vale - Voisey's Bay Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CALA Sample No. : PC0040491 Received : 30 Jun 2023 Voisey's Bay Mine Site, P.O. Box 7001, Stn. C Happy Valley Lab Number : 02567632 Diagnosed : 04 Jul 2023 Goose Bay, NL ISO 17025:2017 Accredited Laboratory Unique Number : 5604678 Diagnostician : Wes Davis CA A0P 1C0 Test Package : IND 2 (Additional Tests: KV100, PQ, PrtCount, TAN Man, VI) Contact: Robert Feltham To discuss this sample report, contact Customer Service at 1-800-268-2131. robert.feltham@vale.com Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: Validity of results and interpretation are based on the sample and information as supplied. F: x:

Apr18/23

13/7