


PROBLEM SUMMARY


Area 1440 Machine Id 1440-5512-4003 - COPPER REGRIND MILL


Drive End Gear Reducer

PETRO CANADA ENDURATEX EP 220 (55 GAL)


COMPONENT CONDITION SUMMARY








Viscosity @ 100°C 40 35 () 30 St (100°C) S2 52 Abnormal 20-Base Abnormal 15 Jan 16/07 Sep4/22 Dec22/08 Mav/28/19 Jun24/21 Vov19/18 Apr27/23 Nov26/17





RECOMMENDATION

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

PROBLEIVIATI	0 IESI	RESULI	3			
Sample Status				ABNORMAL	SEVERE	ATTENTION
Water	%	ASTM D6304*	>0.1	A 0.625		
ppm Water	ppm	ASTM D6304*	>1000	6251.1		
Particles >4µm		ASTM D7647	>20000	A 132472	🔺 151640	<u> </u>
Particles >6µm		ASTM D7647	>5000	A 37071	69069	3617
Particles >14µm		ASTM D7647	>640	<u> </u>	<u> </u>	137
Oil Cleanliness		ISO 4406 (c)	>21/19/16	<u> </u>	• 24/23/18	🔺 22/19/14
Appearance	scalar	Visual*	NORML	🔺 MILKY	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	.2%	NEG	NEG

Customer Id: INCVOS Sample No.: PC0040489 Lab Number: 02567633 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS								
Action	Status	Date	Done By	Description				
Change Filter			?	We recommend you service the filters on this component.				
Resample			?	We recommend an early resample to monitor this condition.				
Check Breathers			?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.				
Check Water Access			?	We advise that you check for the source of water entry.				
Check Seals			?	Check seals and/or filters for points of contaminant entry.				
Filter Fluid			?	We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil.				

HISTORICAL DIAGNOSIS

27 Apr 2023 Diag: Kevin Marson



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Viscosity of sample indicates oil is within ISO 320 range, advise investigate. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



view report

16 Jan 2023 Diag: Kevin Marson

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. Viscosity of sample indicates oil is within ISO 320 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

04 Sep 2022 Diag: Kevin Marson

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. Viscosity of sample indicates oil is within ISO 320 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT

Area 1440 Machine Id 1440-5512-4003 - COPPER REGRIND MILL

Drive End Gear Reducer

PETRO CANADA ENDURATEX EP 220 (55 GAL)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. There is a moderate concentration of water present in the oil.

Fluid Condition

Viscosity of sample indicates oil is within ISO 320 range, advise investigate. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



SAMPLE INFOR	MATION	method	limit/base	current	history 1	history 2
Sample Number		Client Info		PC0040489	PC0057684	PC0058643
Sample Date		Client Info		20 Jun 2023	27 Apr 2023	16 Jan 2023
Machine Age	yrs	Client Info		0	0	0
Oil Age	yrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	SEVERE	ATTENTION
WEAR METAL	S	method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185(m)	>150	39	3	75
Chromium	ppm	ASTM D5185(m)	>10	<1	0	<1
Nickel	ppm	ASTM D5185(m)	>10	<1	0	2
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		<1	0	0
Aluminum	ppm	ASTM D5185(m)	>25	<1	0	0
Lead	ppm	ASTM D5185(m)	>100	0	0	0
Copper	ppm	ASTM D5185(m)	>50	2	<1	3
Tin	ppm	ASTM D5185(m)	>10	0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	<1
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m) ASTM D5185(m)		0	0	0
ADDITIVES	ppm	method	limit/base	-	history 1	history 2
Boron	ppm	ASTM D5185(m)	60	52	61	29
Barium	ppm	ASTM D5185(m)		0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)		<1	0	<1
Magnesium		ASTM D5185(m)	0	<1	0	<1
Calcium	ppm	ASTM D5185(m)		4	0	5
	ppm				269	253
Phosphorus	ppm	ASTM D5185(m)	270	259 6		
Zinc	ppm	ASTM D5185(m)		-	2	13
Sulfur	ppm	ASTM D5185(m)	11200	5811	5645	5769
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185(m)	>50	8	7	5
Sodium	ppm	ASTM D5185(m)		1	0	<1
Potassium	ppm	ASTM D5185(m)	>20	2	<1	<1
Water	%	ASTM D6304*	>0.1	0.625		
ppm Water	ppm	ASTM D6304*	>1000	▲ 6251.1		
FLUID CLEAN	LINESS		limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647	>20000	<u> </u>	🔺 151640	<u> </u>
Particles >6µm		ASTM D7647	>5000	<u> </u>	b 59069	3617
Particles >14µm		ASTM D7647	>640	🔺 1016	A 2205	137
Particles >21µm		ASTM D7647	>160	82	171	24

ASTM D7647 >40

ASTM D7647 >10

ISO 4406 (c) >21/19/16 🔺

Particles >38µm

Particles >71µm

Oil Cleanliness

Contact/Location: Robert Feltham - INCVOS

2

0

24/23/18

2

0

24/22/17

0


0


▲ 22/19/14




OIL ANALYSIS REPORT

T26	FLUID DEGRAD	DATION	method	limit/base	current	history 1	history 2
-24 -22 😨	Acid Number (AN)	mg KOH/g	ASTM D974*	0.40	0.56	0.35	0.32
-20 -18 1999 Cleanliness Code -14 -14 -12 ss Code -10 -10 -10 -10 -10 -10 -10 -10 -10 -10	VISUAL		method	limit/base	current	history 1	history 2
-18 999 C	White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
-14 lin	Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
-12 SS Co	Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
10 8	Silt	scalar	Visual*	NONE	NONE	NONE	NONE
716	Debris	scalar	Visual*	NONE	VLITE	NONE	NONE
τιμ	Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
	Appearance	scalar	Visual*	NORML	🔺 MILKY	NORML	NORML
	Odor	scalar	Visual*	NORML	NORML	NORML	NORML
	Emulsified Water	scalar	Visual*	>0.1	<mark>/</mark> .2%	NEG	NEG
1	Free Water	scalar	Visual*		NEG	NEG	NEG
1	FLUID PROPE	RTIES	method	limit/base	current	history 1	history 2
	Visc @ 40°C	cSt	ASTM D7279(m)	220	327	324	329
23	Visc @ 100°C	cSt	ASTM D7279(m)	19.35	34.4	24.9	25.1
Apr27/23	Viscosity Index (VI)	Scale	ASTM D2270*	99	148	98	98
	SAMPLE IMAG	ES	method	limit/base	current	history 1	history 2
~	Color						
1	Bottom						\bigcirc







: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Vale - Voisey's Bay Sample No. : PC0040489 Received : 30 Jun 2023 Voisey's Bay Mine Site, P.O. Box 7001, Stn. C Happy Valley Lab Number : 02567633 Diagnosed : 05 Jul 2023 Goose Bay, NL ISO 17025:2017 Accredited Laboratory Unique Number : 5604679 Diagnostician : Kevin Marson CA A0P 1C0 Test Package : IND 2 (Additional Tests: KF, KV100, TAN Man, VI) Contact: Robert Feltham To discuss this sample report, contact Customer Service at 1-800-268-2131. robert.feltham@vale.com Т: Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied. F: x: