


Machine Id
JENBACHER 1351185
Component
Natural Gas Engine
Fluid
PETRO CANADA SENTRON CG 40 (--- GAL)



DIAGNOSIS

Recommendation

We advise that you check the air filter, air induction system, and any areas where dirt may enter the component. We recommend that you drain the oil from the component if this has not already been done. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All other component wear rates are normal.

Contamination

There is a moderate concentration of dirt present in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.

SAMPLE INFORMATION method limit/base current history 1 history 2

Sample Number	Client Info	PC0070717	PC0070715	PC0070721
Sample Date	Client Info	04 Jul 2023	02 May 2023	16 Dec 2022
Machine Age	hrs	Client Info	33072	31752
Oil Age	hrs	Client Info	1406	92
Oil Changed	Client Info	Not Chngd	Changed	Changed
Sample Status		ABNORMAL	NORMAL	NORMAL

WEAR METALS method limit/base current history 1 history 2

Iron	ppm	ASTM D5185(m)	>20	3	2	2
Chromium	ppm	ASTM D5185(m)	>5	<1	0	0
Nickel	ppm	ASTM D5185(m)	>2	<1	0	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)	>3	0	0	0
Aluminum	ppm	ASTM D5185(m)	>15	2	2	3
Lead	ppm	ASTM D5185(m)	>20	0	<1	0
Copper	ppm	ASTM D5185(m)	>15	<1	0	0
Tin	ppm	ASTM D5185(m)	>5	2	<1	<1
Antimony	ppm	ASTM D5185(m)		0	0	<1
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES method limit/base current history 1 history 2

Boron	ppm	ASTM D5185(m)	0	2	2	1
Barium	ppm	ASTM D5185(m)	1	0	0	0
Molybdenum	ppm	ASTM D5185(m)	2	2	1	1
Manganese	ppm	ASTM D5185(m)	1	0	<1	<1
Magnesium	ppm	ASTM D5185(m)	9	23	20	20
Calcium	ppm	ASTM D5185(m)	2712	2929	2873	2850
Phosphorus	ppm	ASTM D5185(m)	292	295	288	286
Zinc	ppm	ASTM D5185(m)	342	341	306	312
Sulfur	ppm	ASTM D5185(m)	2575	2623	2649	2637
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS method limit/base current history 1 history 2

Silicon	ppm	ASTM D5185(m)	>100	▲ 103	14	29
Sodium	ppm	ASTM D5185(m)	>20	<1	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	<1	<1	<1


INFRA-RED method limit/base current history 1 history 2

Soot %	%	ASTM D7844*	>2	0	---	0
Nitration	Abs/cm	ASTM D7624*	>20	5.2	---	3.7
Sulfation	Abs/.1mm	ASTM D7415*	>20	17.2	---	14.4

FLUID DEGRADATION method limit/base current history 1 history 2

Oxidation	Abs/.1mm	ASTM D7414*	>20	9.2	---	6.3
Acid Number (AN)	mg KOH/g	ASTM D974*	0.98	1.86	0.52	1.12
Base Number (BN)	mg KOH/g	ASTM D2896*	8.1	7.22	8.15	7.70
i-pH	Scale 0-14	ASTM D7946*	<4.5	5.00	5.85	6184













OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history 1	history 2
Emulsified Water	scalar	Visual*	>.2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D7279(m)	125.8	123	120
Visc @ 100°C	cSt	ASTM D7279(m)	13.5	13.3	13.3
Viscosity Index (VI)	Scale	ASTM D2270*	105	105	104

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CHALEUR REGIONAL SERVICE COMMISSION
Sample No. : PC0070717 **Received** : 05 Jul 2023
Lab Number : 02567962 **Diagnosed** : 06 Jul 2023
Unique Number : 5605008 **Diagnostician** : Kevin Marson
Test Package : MOB 2 (Additional Tests: i-pH, KV40, TAN Auto, TAN Man, VI)

1300 RTE 360
 ALLARDVILLE, NB
 CA E8L 1H5
 Contact: Yvon Richard
 yvon.richard@csrchaleurssc.ca
 T: (506)725-2402
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.