

OIL ANALYSIS REPORT

- Sam

Sample Rating Trend

NORMAL



MP COMPRESSOR

Component

Compressor

NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jul2023	Jul2023		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number		Client Info		PC	PC	
Sample Date		Client Info		04 Jul 2023	01 Jul 2023	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
WEAR METALS	S	method	limit/base	current	history 1	history 2
PQ		ASTM D8184*		0	0	
Iron	ppm	ASTM D5185(m)	>50	0	<1	
Chromium	ppm	ASTM D5185(m)	>5	0	0	
Nickel	ppm	ASTM D5185(m)		0	0	
Titanium	ppm	ASTM D5185(m)		0	0	
Silver	ppm	ASTM D5185(m)		0	0	
Aluminum	ppm	ASTM D5185(m)	>15	0	0	
Lead	ppm	ASTM D5185(m)	>65	0	<1	
Copper	ppm	ASTM D5185(m)	>65	<1	<1	
Tin	ppm	ASTM D5185(m)	>10	0	0	
Antimony	ppm	ASTM D5185(m)		0	0	
Vanadium	ppm	ASTM D5185(m)		0	0	
Beryllium	ppm	ASTM D5185(m)		0	0	
Cadmium	ppm	ASTM D5185(m)		0	0	
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185(m)		<1	0	
Barium	ppm	ASTM D5185(m)		0	0	
Molybdenum	ppm	ASTM D5185(m)		0	0	
Manganese	ppm	ASTM D5185(m)		0	0	
Magnesium	ppm	ASTM D5185(m)		<1	<1	
Calcium	ppm	ASTM D5185(m)		<1	<1	
Phosphorus	ppm	ASTM D5185(m)		84	84	
Zinc	ppm	ASTM D5185(m)		2	2	
Sulfur	ppm	ASTM D5185(m)		443	446	
Lithium	ppm	ASTM D5185(m)		<1	<1	
CONTAMINAN	TS	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185(m)	>35	2	2	
Sodium	ppm	ASTM D5185(m)		<1	0	
Potassium	ppm	ASTM D5185(m)	>20	0	<1	
Water	%	ASTM D6304*	>0.1	0.001	0.001	
ppm Water	ppm	ASTM D6304*	>1000	8.3	6.5	
FLUID DEGRAD	OATION	method	limit/base	current	history 1	history 2

Acid Number (AN)


mg KOH/g ASTM D974*

0.05

0.06



OIL ANALYSIS REPORT





CALA ISO 17025:2017 Accredited

Laboratory

Sample No. Lab Number **Unique Number**

: PC

: 02567998 : 5605044

Received : 05 Jul 2023 Diagnosed : 05 Jul 2023

: Kevin Marson Diagnostician Test Package : MAR 2 (Additional Tests: KF, KV100, TAN Man, VI)

To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Scotia Centre, 235 Water Strret

St. John's, NL CA A1C 1B6

Contact: Deanne Badcock dbadcock@suncor.com T: (709)778-3843

F: (709)724-2784