


PROBLEM SUMMARY

Sample Rating Trend

VISCOSITY




Area
1460
Machine Id
1460-5666-4001 - HG Ni THICKENER MECH PLANETARY
Component
Reduction Gear
Fluid
PETRO CANADA ENDURATEX XL 68/220 (20 LTR)




COMPONENT CONDITION SUMMARY


▲ Viscosity @ 100°C



▲ Viscosity @ 40°C



▲ Additives



RECOMMENDATION

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ATTENTION	ATTENTION
Zinc	ppm	ASTM D5185(m)	▲ 116	22	15
Visc @ 40°C	cSt	ASTM D7279(m)	▲ 95.4	140	164
Visc @ 100°C	cSt	ASTM D7279(m)	▲ 15.4	19.1	20.6

Customer Id: INCVOS
Sample No.: PC0057974
Lab Number: 02568901
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.

HISTORICAL DIAGNOSIS

20 Oct 2021 Diag: Kevin Marson

WEAR



Resample at the next service interval to monitor. Iron ppm levels are noted. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. All other component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



20 Jun 2021 Diag: Wes Davis

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



17 Mar 2021 Diag: Wes Davis

ISO




Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6µm are severely high. Particles >4µm are abnormally high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Area
1460
Machine Id
1460-5666-4001 - HG Ni THICKENER MECH PLANETARY
Component
Reduction Gear
Fluid
PETRO CANADA ENDURATEX XL 68/220 (20 LTR)



DIAGNOSIS

Recommendation
Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Fluid Condition
Viscosity of sample indicates oil is within ISO 100 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION	method	limit/base	current	history 1	history 2
Sample Number	Client Info		PC0057974	PC0030028	PC0040209
Sample Date	Client Info		26 Jun 2023	20 Oct 2021	20 Jun 2021
Machine Age	mths	Client Info	0	0	0
Oil Age	mths	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ATTENTION	ATTENTION

WEAR METALS	method	limit/base	current	history 1	history 2
PQ	ASTM D8184*		0	0	0
Iron	ppm	ASTM D5185(m) >150	113	▲ 204	102
Chromium	ppm	ASTM D5185(m) >10	<1	1	<1
Nickel	ppm	ASTM D5185(m) >10	1	1	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	<1	<1	<1
Aluminum	ppm	ASTM D5185(m) >25	<1	0	<1
Lead	ppm	ASTM D5185(m) >100	0	<1	<1
Copper	ppm	ASTM D5185(m) >50	4	2	<1
Tin	ppm	ASTM D5185(m) >10	0	0	0
Antimony	ppm	ASTM D5185(m) >5	0	<1	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0


ADDITIVES	method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185(m)	5	9	10
Barium	ppm	ASTM D5185(m)	0	0	<1
Molybdenum	ppm	ASTM D5185(m)	<1	<1	<1
Manganese	ppm	ASTM D5185(m)	<1	1	<1
Magnesium	ppm	ASTM D5185(m)	<1	0	<1
Calcium	ppm	ASTM D5185(m)	4	2	3
Phosphorus	ppm	ASTM D5185(m) 240	323	355	345
Zinc	ppm	ASTM D5185(m)	▲ 116	22	15
Sulfur	ppm	ASTM D5185(m) 4060	4127	5342	5253
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185(m) >50	2	1	1
Sodium	ppm	ASTM D5185(m)	<1	0	<1
Potassium	ppm	ASTM D5185(m) >20	0	<1	<1


FLUID CLEANLINESS	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647	>20000	159099	176785	▲ 35083
Particles >6µm	ASTM D7647	>5000	57972	34501	2579
Particles >14µm	ASTM D7647	>640	441	299	28
Particles >21µm	ASTM D7647	>160	49	12	7
Particles >38µm	ASTM D7647	>40	5	0	1
Particles >71µm	ASTM D7647	>10	1	0	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	24/23/16	25/22/15	▲ 22/19/12

OIL ANALYSIS REPORT


▲ Viscosity @ 100°C




▲ Viscosity @ 40°C




▲ Additives



Particle Count



Acid Number



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0057974
Lab Number : 02568901
Unique Number : 5605947
Test Package : IND 2 (Additional Tests: KV100, PQ, PrtCount, TAN Man, VI)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Vale - Voisey's Bay
 Voisey's Bay Mine Site, P.O. Box 7001, Stn. C Happy Valley
 Goose Bay, NL
 CA A0P 1C0
 Contact: Robert Feltham
 robert.feltham@vale.com

T:
F: x:

FLUID DEGRADATION

method	limit/base	current	history 1	history 2	
Acid Number (AN) mg KOH/g	ASTM D974*	0.9	0.56	0.63	0.58

VISUAL

method	limit/base	current	history 1	history 2		
White Metal	scalar	Visual*	NONE	NONE	VLITE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	VLITE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	VLITE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES

method	limit/base	current	history 1	history 2		
Visc @ 40°C	cSt	ASTM D7279(m)	150.4	▲ 95.4	140	164
Visc @ 100°C	cSt	ASTM D7279(m)	22.28	▲ 15.4	19.1	20.6
Viscosity Index (VI)	Scale	ASTM D2270*	176	171	155	147

SAMPLE IMAGES

