

PROBLEM SUMMARY

Sample Rating Trend




Main Power Generation [450169585]

Generator - MPG (Port) Lube Oil System (S/N Sample Tag XX-80201-S1)

Component **Turbine**

PETRO CANADA TURBOFLO 32 (8300 LTR)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MAR 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

PROBLEMATIC	TEST RESULT	S			
Sample Status			ABNORMAL	NORMAL	NORMAL
Particles >6µm	ASTM D7647	>640	<u> </u>	58	68
Particles >14μm	ASTM D7647	>80	A 89	6	7
Oil Cleanliness	ISO 4406 (c)	>/16/13	19/18/14	15/13/10	15/13/10

Customer Id: TERHAM Sample No.: PC0040111 Lab Number: 02569711 Test Package: MAR 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.
Resample			?	We recommend an early resample to monitor this condition.
Contact Required			?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert			?	NOTE: We recommend using MAR 3 test kits,

HISTORICAL DIAGNOSIS

25 May 2023 Diag: Kevin Marson





Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.Component wear rates appear to be normal (unconfirmed). The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



24 Apr 2023 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MAR 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.Component wear rates appear to be normal (unconfirmed). The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

/FS

10 IVIC



13 Mar 2023 Diag: Kevin Marson

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. The fluid was specified as PETRO CANADA TURBOFLO 32, however, a fluid match indicates that this fluid is ISO 32 Gas / Steam Turbine Oil. Please confirm the oil type and grade on your next sample. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MAR 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.Component wear rates appear to be normal (unconfirmed). The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






OIL ANALYSIS REPORT

Main Power Generation [450169585]

Generator - MPG (Port) Lube Oil System (S/N Sample Tag XX-80201-S1)

Turbine

PETRO CANADA TURBOFLO 32 (8300 LTR)





DIAGNOSIS

Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MAR 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

Wear

Component wear rates appear to be normal (unconfirmed).

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code.


Fluid Condition


The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC0040111	PC	PC PC
Sample Date		Client Info		04 Jul 2023	25 May 2023	24 Apr 2023
Machine Age	hrs	Client Info		04 001 2025	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed	0	Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS	S	method	limit/base	current	history1	history2
PQ		ASTM D8184*		0	0	0
Iron	ppm	ASTM D5185(m)	>15	<1	<1	<1
Chromium	ppm	ASTM D5185(m)	>4	0	0	0
Nickel	ppm	ASTM D5185(m)	>2	0	0	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>10	0	0	0
Lead	ppm	ASTM D5185(m)		0	0	0
Copper	ppm	ASTM D5185(m)	>5	<1	<1	<1
Tin	ppm	ASTM D5185(m)	>5	1	1	1
Antimony	ppm	ASTM D5185(m)		0	<1	<1
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	0	0	0
Barium	ppm	ASTM D5185(m)	0	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)		0	0	0
Magnesium	ppm	ASTM D5185(m)	0	<1	0	0
Calcium	ppm	ASTM D5185(m)	0	1	0	0
Phosphorus	ppm	ASTM D5185(m)	120	279	292	280
Zinc	ppm	ASTM D5185(m)	0.0	2	<1	<1
Sulfur	ppm	ASTM D5185(m)	0	504	529	505
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	<1	<1	<1
Sodium	ppm	ASTM D5185(m)		<1	0	<1
Potassium	ppm	ASTM D5185(m)	>20	<1	0	0
FLUID CLEANL	INESS	method	limit/base	current	history1	history2
		4 OT1 4 D70 47		4405	220	232
Particles >4µm		ASTM D7647		4495	220	202
Particles >4µm Particles >6µm		ASTM D7647 ASTM D7647	>640	4495 1511	58	68
·			>640 >80			
Particles >6μm		ASTM D7647	>80	<u> </u>	58	68
Particles >6μm Particles >14μm		ASTM D7647 ASTM D7647	>80	▲ 1511 ▲ 89	58 6	68 7
Particles >6µm Particles >14µm Particles >21µm		ASTM D7647 ASTM D7647 ASTM D7647	>80 >20 >4	▲ 1511 ▲ 89 16	58 6 2	68 7 2



OIL ANALYSIS REPORT





Acie	d Num	ber						
(B/HOX)							Λ	
Acid Number (mg K0H/g)	1_	11	1	Λ	\wedge	~~	/ V	1
N O.05 - Base		W	.uu:30	~				-
0.00		V 1	6	- 61	- 02	- 02	8	_
T/61lnC	Feb22/1	0ct30/18	Mar20/1	Sep7/1	Feb25/2	Sep6/20	Feb26/2:	


Viso	osity	@ 100)°C					
7 - Abno	ırmal							
() 6 Base 5.5 Abno								-
₹5 5 Abno	rmal							
3.5								
Juli 9/1	Feb22/18	0ct30/18	Mar20/19	Sep7/15	Feb25/20	Sep6/20	Feb26/23	

Base	Base	Viscosity	@ 40°	C				
Abnormal	Abnormal	Abnormal	+++++	++++				
Abnormal	Abnormal	Base						
Abnormal	Abnormal							
		Abnormal						٧
Juli 9/17 Feb 22/18 Mar 20/19 Sep 7/19 Sep 6/20 Feb 25/20			Dert30	Ja J	S	- 8	S	균

FLUID DEGRAD	OITAC	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.04	0.08	0.09	0.09
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.03	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG
FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	34.0	31.5	33.6	33.6
Visc @ 100°C	cSt	ASTM D7279(m)	5.59	5.7	5.7	5.6
Viscosity Index (VI)	Scale	ASTM D2270*	110	122	109	103
SAMPLE IMAG	ES	method	limit/base	current	history1	history2
						want Date April a

Color

Bottom





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number Unique Number : 5606757

: PC0040111 : 02569711

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9

Received Diagnosed

: 13 Jul 2023 : 14 Jul 2023

Diagnostician : Kevin Marson

Test Package : MAR 2 (Additional Tests: KV100, PQ, TAN Man, VI) To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Suncor - Terra Nova Projects Scotia Centre, 235 Water Strret St. John's, NL

> CA A1C 1B6 Contact: Josh Hynes joshynes@suncor.com T: (709)778-3575

F: (709)724-2835