


# PROBLEM SUMMARY

Sample Rating Trend



**INSOLUBLES**




Machine Id  
**IMM #22 (S/N 6364927)**

Component  
**Hydraulic System**

Fluid  
**PETRO CANADA HYDREX AW 46 (4000 LTR)**

## COMPONENT CONDITION SUMMARY

### ▲ Varnish Potential



## RECOMMENDATION

We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>ABNORMAL</b>	<b>SEVERE</b>	<b>SEVERE</b>
MPC Varnish Potential	Scale	ASTM D7843(m)*	>15	▲ 38	● 47	● 45

**Customer Id:** ROPOAK  
**Sample No.:** PC0076924  
**Lab Number:** 02571213  
**Test Package:** IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We recommend an early resample to monitor this condition.
Contact Required	---	---	?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert	---	---	?	NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.
Filter Fluid	---	---	?	We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level.

## HISTORICAL DIAGNOSIS

### 21 Sep 2022 Diag: Kevin Marson

#### INSOLUBLES



We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition. All component wear rates are normal. MPC (Membrane Patch Colorimetry) test indicates a high concentration of varnish present. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The AN level is acceptable for this fluid.

[view report](#)



### 28 Oct 2021 Diag: Kevin Marson

#### INSOLUBLES



We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition. All component wear rates are normal. MPC (Membrane Patch Colorimetry) test indicates a high concentration of varnish present. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The AN level is acceptable for this fluid.

[view report](#)



### 10 Jun 2021 Diag: Kevin Marson

#### INSOLUBLES



We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition. All component wear rates are normal. MPC (Membrane Patch Colorimetry) test indicates a high concentration of varnish present. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The AN level is acceptable for this fluid.

[view report](#)






Machine Id  
**IMM #22 (S/N 6364927)**

Component  
**Hydraulic System**

Fluid  
**PETRO CANADA HYDREX AW 46 (4000 LTR)**



**DIAGNOSIS**

**Recommendation**

We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.

**Wear**

Component wear rates appear to be normal (unconfirmed).

**Contamination**

MPC (Membrane Patch Colorimetry) test indicates a moderate concentration of varnish present. The system cleanliness is acceptable for your target ISO 4406 cleanliness code.

**Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed).

**SAMPLE INFORMATION**

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PC0076924</b>	PC0062446	PC0052974
Sample Date	Client Info	<b>11 Jul 2023</b>	21 Sep 2022	28 Oct 2021
Machine Age	mths	Client Info	0	0
Oil Age	mths	Client Info	72	0
Oil Changed	Client Info	<b>N/A</b>	Not Changd	N/A
Sample Status		<b>ABNORMAL</b>	SEVERE	SEVERE

**WEAR METALS**

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185(m) >20	<b>&lt;1</b>	<1	<1
Chromium ppm	ASTM D5185(m) >20	<b>0</b>	0	0
Nickel ppm	ASTM D5185(m) >20	<b>&lt;1</b>	0	<1
Titanium ppm	ASTM D5185(m)	<b>0</b>	0	0
Silver ppm	ASTM D5185(m)	<b>0</b>	0	0
Aluminum ppm	ASTM D5185(m) >20	<b>0</b>	0	0
Lead ppm	ASTM D5185(m) >20	<b>0</b>	0	<1
Copper ppm	ASTM D5185(m) >20	<b>2</b>	2	2
Tin ppm	ASTM D5185(m) >20	<b>0</b>	0	0
Antimony ppm	ASTM D5185(m)	<b>0</b>	<1	<1
Vanadium ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium ppm	ASTM D5185(m)	<b>0</b>	0	0

**ADDITIVES**

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185(m) 0	<b>&lt;1</b>	<1	<1
Barium ppm	ASTM D5185(m) 0	<b>0</b>	0	0
Molybdenum ppm	ASTM D5185(m) 0	<b>0</b>	0	0
Manganese ppm	ASTM D5185(m) 0	<b>0</b>	0	0
Magnesium ppm	ASTM D5185(m) 0	<b>&lt;1</b>	0	<1
Calcium ppm	ASTM D5185(m) 50	<b>15</b>	7	21
Phosphorus ppm	ASTM D5185(m) 330	<b>319</b>	324	336
Zinc ppm	ASTM D5185(m) 430	<b>248</b>	221	279
Sulfur ppm	ASTM D5185(m) 760	<b>596</b>	586	639
Lithium ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1

**CONTAMINANTS**


method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185(m) >15	<b>&lt;1</b>	<1	<1
Sodium ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1
Potassium ppm	ASTM D5185(m) >20	<b>&lt;1</b>	0	<1

**FLUID CLEANLINESS**

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	<b>1146</b>	1192	253
Particles >6µm	ASTM D7647 >1300	<b>255</b>	313	51
Particles >14µm	ASTM D7647 >160	<b>20</b>	13	5
Particles >21µm	ASTM D7647 >40	<b>6</b>	2	2
Particles >38µm	ASTM D7647 >10	<b>0</b>	0	0
Particles >71µm	ASTM D7647 >3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	<b>17/15/11</b>	17/15/11	15/13/10

# OIL ANALYSIS REPORT


## ▲ Varnish Potential



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.70	<b>0.37</b>	0.22	0.28
MPC Varnish Potential	Scale	ASTM D7843(m)*	>15	<b>▲ 38</b>	47	45


VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>VLITE</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

## Particle Count



FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46.4	<b>44.7</b>	45.3	45.3
Visc @ 100°C	cSt	ASTM D7279(m)	6.92	<b>7.1</b>	7.1	6.8
Viscosity Index (VI)	Scale	ASTM D2270*	104	<b>118</b>	115	104

## Acid Number




## SAMPLE IMAGES

Color




Bottom




MPC



## Viscosity @ 100°C



## Viscosity @ 40°C




ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0076924 **Received** : 20 Jul 2023  
**Lab Number** : **02571213** **Diagnosed** : 21 Jul 2023  
**Unique Number** : 5616264 **Diagnostician** : Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: KV100, MPC, TAN Man, VI )

**ROPAK PACKAGING CANADA**  
 2240 WYECROFT RD  
 OAKVILLE, ON  
 CA L6L 6M1  
 Contact: Frank Maio  
 Frank.Maio@mauserpackaging.com  
 T: (905)465-9019  
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

MPC (Varnish Test)



Sample Color & Clarity



*This page left intentionally blank*