

PROBLEM SUMMARY

Sample Rating Trend

INSOLUBLES


IMM #6 (S/N 2198290)


Component **Y Hydraulic System**

Fluid

PETRO CANADA HYDREX AW 46 (4000 LTR)

COMPONENT CONDITION SUMMARY





14

5

RECOMMENDATION

We recommend you service the filters on this component. We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.

PROBLEMATIC TEST RESULTS									
Sample Status				ABNORMAL	NORMAL	NORMAL			
Particles >4μm		ASTM D7647	>5000	<u> </u>	3161	4558			
Particles >6µm		ASTM D7647	>1300	▲ 3662	720	1088			
Oil Cleanliness		ISO 4406 (c)	>19/17/14	22/19/12	19/17/13	19/17/13			

MPC Varnish Potential Scale ASTM D7843(m)* >15

Customer Id: ROPOAK Sample No.: PC0076956 Lab Number: 02571217 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.
Resample			?	We recommend an early resample to monitor this condition.
Contact Required			?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert			?	NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.
Filter Fluid			?	We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level.

HISTORICAL DIAGNOSIS

21 Sep 2022 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



10 May 2022 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. MPC (Membrane Patch Colorimetry) test indicates acceptable levels of varnish present. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



28 Oct 2021 Diag: Wes Davis

NORMAL




Resample at the next service interval to monitor.All component wear rates are normal. MPC (Membrane Patch Colorimetry) test indicates acceptable levels of varnish present. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

IMM #6 (S/N 2198290)

Componen

Hydraulic System

PETRO CANADA HYDREX AW 46 (4000 LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.

Wear

Component wear rates appear to be normal (unconfirmed).

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. MPC (Membrane Patch Colorimetry) test indicates a moderate concentration of varnish present.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed). The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

R)		May2016 Sep2	017 Jun2019 Dec2019	Jun2020 Mar2021 Oct2021	Sep 2022	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC0076956	PC0062461	PC0044699
Sample Date		Client Info		11 Jul 2023	21 Sep 2022	10 May 2022
Machine Age	mths	Client Info		0	0	0
Oil Age	mths	Client Info		0	3	0
Oil Changed		Client Info		N/A	Changed	N/A
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>20	<1	<1	<1
Chromium	ppm	ASTM D5185(m)	>20	<1	0	0
Nickel	ppm	ASTM D5185(m)	>20	<1	0	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>20	0	0	0
Lead	ppm	ASTM D5185(m)	>20	0	0	0
Copper	ppm	ASTM D5185(m)	>20	<1	<1	<1
Tin	ppm	ASTM D5185(m)	>20	0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	<1	<1	<1
Barium	ppm	ASTM D5185(m)	0	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0	0
Magnesium	ppm	ASTM D5185(m)	0	1	0	0
Calcium	ppm	ASTM D5185(m)	50	38	38	40
Phosphorus	ppm	ASTM D5185(m)	330	359	345	333
Zinc	ppm	ASTM D5185(m)	430	402	382	402
Sulfur	ppm	ASTM D5185(m)	760	742	723	716
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	0	0	0
Sodium	ppm	ASTM D5185(m)		0	0	0
Potassium	ppm	ASTM D5185(m)	>20	<1	0	<1
FLUID CLEANL	INESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	<u> </u>	3161	4558
Particles >6µm		ASTM D7647	>1300	△ 3662	720	1088
Particles >14µm		ASTM D7647	>160	39	64	63
Particles >21µm		ASTM D7647	>40	2	18	9
Particles >38μm		ASTM D7647	>10	0	1	0
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<u>22/19/12</u>	19/17/13	19/17/13



OIL ANALYSIS REPORT





CALA ISO 17025:2017 Accredited

Laboratory Sample No. Lab Number **Unique Number**

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : PC0076956 : 02571217 : 5616268

Received Diagnosed

: 20 Jul 2023 : 21 Jul 2023 Diagnostician : Kevin Marson


Test Package : IND 2 (Additional Tests: KV100, MPC, TAN Man, VI) To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. **ROPAK PACKAGING CANADA** 2240 WYECROFT RD


OAKVILLE, ON CA L6L 6M1

Contact: Frank Maio Frank.Maio@mauserpackaging.com T: (905)465-9019

Validity of results and interpretation are based on the sample and information as supplied.

F:





Report Id: ROPOAK [WCAMIS] 02571217 (Generated: 07/21/2023 13:53:47) Rev: 1

This page left intentionally blank