




Machine Id
IMM #7 (S/N 2175690)


Component
Hydraulic System

Fluid
PETRO CANADA HYDREX AW 46 (4000 LTR)




COMPONENT CONDITION SUMMARY

Varnish Potential



Particle Trend



RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. Resample in 30-45 days to monitor this situation. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	MARGINAL	SEVERE
Particles >4µm	ASTM D7647	>5000	40764	3671	74023
Particles >6µm	ASTM D7647	>1300	6230	599	4645
Oil Cleanliness	ISO 4406 (c)	>19/17/14	23/20/12	19/16/12	23/19/14
MPC Varnish Potential	Scale	ASTM D7843(m)* >15	55	22	42

Customer Id: ROPOAK
Sample No.: PC0076957
Lab Number: 02571218
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Contact Required	---	---	?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert	---	---	?	NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.
Filter Fluid	---	---	?	We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level.

HISTORICAL DIAGNOSIS

21 Sep 2022 Diag: Kevin Marson

INSOLUBLES



We recommend an early resample to monitor this condition. No other corrective action is recommended at this time. All component wear rates are normal. MPC (Membrane Patch Colorimetry) test indicates a light concentration of varnish present. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



10 May 2022 Diag: Kevin Marson

INSOLUBLES



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Oil Cleanliness are severely high. MPC Varnish Potential contamination levels are severely high. Particles >4µm are severely high. Particles >6µm are abnormally high. MPC (Membrane Patch Colorimetry) test indicates a high concentration of varnish present. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

[view report](#)



28 Oct 2021 Diag: Kevin Marson

INSOLUBLES



We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Component wear rates appear to be normal (unconfirmed). MPC (Membrane Patch Colorimetry) test indicates a moderate concentration of varnish present. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The AN level is acceptable for this fluid.

[view report](#)






Machine Id
IMM #7 (S/N 2175690)

Component
Hydraulic System

Fluid
PETRO CANADA HYDREX AW 46 (4000 LTR)



DIAGNOSIS

Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. Resample in 30-45 days to monitor this situation. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.

Wear

Component wear rates appear to be normal (unconfirmed).

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. MPC (Membrane Patch Colorimetry) test indicates a high concentration of varnish present.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed). The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PC0076957	PC0062460	PC0044226
Sample Date	Client Info	11 Jul 2023	21 Sep 2022	10 May 2022
Machine Age	hrs	0	0	0
Oil Age	hrs	0	60	0
Oil Changed	Client Info	N/A	Filtered	N/A
Sample Status		SEVERE	MARGINAL	SEVERE

WEAR METALS

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185(m) >40	1	<1	7
Chromium ppm	ASTM D5185(m) >4	<1	0	0
Nickel ppm	ASTM D5185(m) >20	<1	0	<1
Titanium ppm	ASTM D5185(m)	0	0	0
Silver ppm	ASTM D5185(m)	0	0	0
Aluminum ppm	ASTM D5185(m) >4	0	0	0
Lead ppm	ASTM D5185(m) >10	0	0	0
Copper ppm	ASTM D5185(m) >60	<1	<1	<1
Tin ppm	ASTM D5185(m) >4	0	0	0
Antimony ppm	ASTM D5185(m)	0	0	0
Vanadium ppm	ASTM D5185(m)	0	0	0
Beryllium ppm	ASTM D5185(m)	0	0	0
Cadmium ppm	ASTM D5185(m)	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185(m) 0	<1	<1	0
Barium ppm	ASTM D5185(m) 0	0	0	0
Molybdenum ppm	ASTM D5185(m) 0	0	0	0
Manganese ppm	ASTM D5185(m) 0	0	0	0
Magnesium ppm	ASTM D5185(m) 0	2	0	0
Calcium ppm	ASTM D5185(m) 50	36	39	38
Phosphorus ppm	ASTM D5185(m) 330	359	340	343
Zinc ppm	ASTM D5185(m) 430	393	377	399
Sulfur ppm	ASTM D5185(m) 760	733	716	718
Lithium ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS


method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185(m) >20	0	0	<1
Sodium ppm	ASTM D5185(m)	0	0	0
Potassium ppm	ASTM D5185(m) >20	<1	0	<1

FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	40764	3671	74023
Particles >6µm	ASTM D7647 >1300	6230	599	4645
Particles >14µm	ASTM D7647 >160	32	26	157
Particles >21µm	ASTM D7647 >40	4	4	22
Particles >38µm	ASTM D7647 >10	0	1	0
Particles >71µm	ASTM D7647 >3	0	0	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	23/20/12	19/16/12	23/19/14

OIL ANALYSIS REPORT


Varnish Potential




Particle Count




Particle Trend



Acid Number



Viscosity @ 100°C




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.70	0.51	0.35	0.35
MPC Varnish Potential	Scale	ASTM D7843(m)*	>15	55	22	42

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	VLITE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG


FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46.4	45.1	45.4	45.5
Visc @ 100°C	cSt	ASTM D7279(m)	6.92	7.3	7.3	7.4
Viscosity Index (VI)	Scale	ASTM D2270*	104	124	122	126

SAMPLE IMAGES

Color



Bottom



MPC



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0076957 **Received** : 20 Jul 2023
Lab Number : **02571218** **Diagnosed** : 21 Jul 2023
Unique Number : 5616269 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: KV100, MPC, TAN Man, VI)


To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

ROPAK PACKAGING CANADA
 2240 WYECROFT RD
 OAKVILLE, ON
 CA L6L 6M1
 Contact: Frank Maio
 Frank.Maio@mauserpackaging.com
 T: (905)465-9019
 F:

MPC (Varnish Test)



Sample Color & Clarity



This page left intentionally blank