

OIL ANALYSIS REPORT

Sample Rating Trend





Area **222** Machine Id **800259**

Fluid

Component 1 Natural Gas Engine

PETRO CANADA DURON GEO LD 15W40 (24 LTR)

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The condition of the oil is acceptable for the time in service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0086803		
Sample Date		Client Info		25 Jul 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS	6	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>50	37		
Chromium	ppm	ASTM D5185(m)	>4	3		
Nickel	ppm	ASTM D5185(m)	>2	<1		
Titanium	ppm	ASTM D5185(m)		<1		
Silver	ppm	ASTM D5185(m)	>3	0		
Aluminum	ppm	ASTM D5185(m)	>9	4		
Lead	ppm	ASTM D5185(m)	>30	2		
Copper	ppm	ASTM D5185(m)	>35	2		
Tin	ppm	ASTM D5185(m)	>4	<1		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	50	9		
Barium	ppm	ASTM D5185(m)	5	0		
Molybdenum	ppm	ASTM D5185(m)	50	113		
Manganese	ppm	ASTM D5185(m)	0	1		
Magnesium	ppm	ASTM D5185(m)	560	782		
Calcium	ppm	ASTM D5185(m)	1510	1629		
Phosphorus	ppm	ASTM D5185(m)	780	895		
Zinc	ppm	ASTM D5185(m)	870	994		
Sulfur	ppm	ASTM D5185(m)	2040	2300		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINAN	ΓS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>+100	8		
Sodium	ppm	ASTM D5185(m)		6		
Potassium	ppm	ASTM D5185(m)	>20	<1		
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*		0		
Nitration	Abs/cm	ASTM D7624*	>20	10.6		
Sulfation	Abs/.1mm	ASTM D7415*	>30	23.3		
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414*	>25	17.0		
VISUAL		method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.1	NEG		
Free Water	scalar	Visual*		NEG		
9.43.39) Rov. 1					Submitted By:	Kim Thompson



OIL ANALYSIS REPORT



Submitted By: Kim Thompson Page 2 of 2