






Machine Id
HOFFMAN HRM001

Component
Unknown Component

Fluid
HOUGHTON DASCOLENE 598 DBR (5000 LTR)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. Please provide more complete information on your next sample. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	---	---
Particles >4µm	ASTM D7647	>5000	141167	---	---
Particles >6µm	ASTM D7647	>1300	91489	---	---
Particles >14µm	ASTM D7647	>160	3336	---	---
Particles >21µm	ASTM D7647	>40	170	---	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	24/24/19	---	---

Customer Id: CAM148GUE
Sample No.: PC0076473
Lab Number: 02572943
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Contact Required	---	---	?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert	---	---	?	Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. NOTE: We recommend using IND 3 test kits,
Information Required	---	---	?	Please provide more complete information on your next sample.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.


HISTORICAL DIAGNOSIS



Machine Id
HOFFMAN HRM001

Component
Unknown Component

Fluid
HOUGHTON DASCOLENE 598 DBR (5000 LTR)



DIAGNOSIS

Recommendation

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. Please provide more complete information on your next sample. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

Wear

Component wear rates appear to be normal (unconfirmed).

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the sample.

Fluid Condition

The sample is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PC0076473	---	---
Sample Date	Client Info	27 Jul 2023	---	---
Machine Age	mths Client Info	3	---	---
Oil Age	mths Client Info	0	---	---
Oil Changed	Client Info	Filtered	---	---
Sample Status		SEVERE	---	---

WEAR METALS

method	limit/base	current	history1	history2
Iron ppm ASTM D5185(m)		32	---	---
Chromium ppm ASTM D5185(m)		<1	---	---
Nickel ppm ASTM D5185(m)		0	---	---
Titanium ppm ASTM D5185(m)		0	---	---
Silver ppm ASTM D5185(m)		0	---	---
Aluminum ppm ASTM D5185(m)		24	---	---
Lead ppm ASTM D5185(m)		0	---	---
Copper ppm ASTM D5185(m)		1	---	---
Tin ppm ASTM D5185(m)		0	---	---
Antimony ppm ASTM D5185(m)		0	---	---
Vanadium ppm ASTM D5185(m)		0	---	---
Beryllium ppm ASTM D5185(m)		0	---	---
Cadmium ppm ASTM D5185(m)		0	---	---

ADDITIVES

method	limit/base	current	history1	history2
Boron ppm ASTM D5185(m)		1	---	---
Barium ppm ASTM D5185(m)		0	---	---
Molybdenum ppm ASTM D5185(m)		0	---	---
Manganese ppm ASTM D5185(m)		7	---	---
Magnesium ppm ASTM D5185(m)		<1	---	---
Calcium ppm ASTM D5185(m)		31	---	---
Phosphorus ppm ASTM D5185(m)		773	---	---
Zinc ppm ASTM D5185(m)		6	---	---
Sulfur ppm ASTM D5185(m)		16716	---	---
Lithium ppm ASTM D5185(m)		<1	---	---

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm ASTM D5185(m)		3	---	---
Sodium ppm ASTM D5185(m)		15	---	---
Potassium ppm ASTM D5185(m)	>20	6	---	---






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm ASTM D7647	>5000	141167	---	---
Particles >6µm ASTM D7647	>1300	91489	---	---
Particles >14µm ASTM D7647	>160	3336	---	---
Particles >21µm ASTM D7647	>40	170	---	---
Particles >38µm ASTM D7647	>10	3	---	---
Particles >71µm ASTM D7647	>3	0	---	---
Oil Cleanliness ISO 4406 (c)	>19/17/14	24/24/19	---	---

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g ASTM D974*		0.10	---	---

OIL ANALYSIS REPORT






VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	VLITE	---
Yellow Metal	scalar	Visual*	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	---
Emulsified Water	scalar	Visual*	NEG	---	---
Free Water	scalar	Visual*	NEG	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	17	15.2	---
Visc @ 100°C	cSt	ASTM D7279(m)	3.5	---	---
Viscosity Index (VI)	Scale	ASTM D2270*	107	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0076473 **Received** : 28 Jul 2023
Lab Number : 02572943 **Diagnosed** : 31 Jul 2023
Unique Number : 5617994 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: KV100, VI)

CAMTAC MFG
 148 ARROW RD
 GUELPH, ON
 CA N1K 1T4
 Contact: Mark Rudden
 mark.rudden@linamar.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.