


PROBLEM SUMMARY


Area
TEAM 1
Machine Id
122108 ID Fan Inboard (S/N 122108 Inboard Brg)
Component
Bearing
Fluid
PETRO CANADA TURBOFLO R&O 150 (1 GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Non-ferrous Metals



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ATTENTION	ABNORMAL	ABNORMAL
Lead	ppm	ASTM D5185(m)	>20	▲ 39	▲ 91	▲ 45

Customer Id: CANDRY
Sample No.: PC0070438
Lab Number: 02575375
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

08 Jun 2023 Diag: Kevin Marson

WEAR



We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. Lead ppm levels are abnormal. Bearing wear is indicated. There is no indication of any contamination in the oil. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



08 Jun 2023 Diag: Kevin Marson

WEAR



We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. Lead ppm levels are abnormal. Bearing wear is indicated. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



05 Apr 2023 Diag: Kevin Marson

WEAR




We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. Lead ppm levels are abnormal. Bearing wear is indicated. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
TEAM 1
Machine Id
122108 ID Fan Inboard (S/N 122108 Inboard Brg)
Component
Bearing
Fluid
PETRO CANADA TURBOFLO R&O 150 (1 GAL)

DIAGNOSIS

▲ Recommendation

Resample at the next service interval to monitor.

▲ Wear

Lead ppm levels are noted. All other component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PC0070438	PC0074859	PC0070186
Sample Date	Client Info	10 Aug 2023	08 Jun 2023	08 Jun 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ATTENTION	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2	
PQ	ASTM D8184*	0	---	0	
Iron	ppm	ASTM D5185(m) >20	5	3	8
Chromium	ppm	ASTM D5185(m) >20	0	0	0
Nickel	ppm	ASTM D5185(m) >20	<1	<1	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	0	0	0
Aluminum	ppm	ASTM D5185(m) >20	<1	<1	<1
Lead	ppm	ASTM D5185(m) >20	▲ 39	▲ 91	▲ 45
Copper	ppm	ASTM D5185(m) >20	2	10	2
Tin	ppm	ASTM D5185(m) >20	<1	1	1
Antimony	ppm	ASTM D5185(m)	0	1	2
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	2	<1	<1
Barium	ppm	ASTM D5185(m)	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)	<1	<1	<1
Magnesium	ppm	ASTM D5185(m)	2	2	1
Calcium	ppm	ASTM D5185(m) 0	6	6	6
Phosphorus	ppm	ASTM D5185(m) 4	8	6	7
Zinc	ppm	ASTM D5185(m) 0	11	7	10
Sulfur	ppm	ASTM D5185(m)	2263	2074	2116
Lithium	ppm	ASTM D5185(m)	<1	<1	<1






CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m) >15	<1	2	2
Sodium	ppm	ASTM D5185(m)	3	<1	3
Potassium	ppm	ASTM D5185(m) >20	<1	1	1

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974* 0.18	0.08	---	0.10

OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	137.1	146	147
Visc @ 100°C	cSt	ASTM D7279(m)	14.19	14.7	14.6
Viscosity Index (VI)	Scale	ASTM D2270*	101	99	97

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0070438 **Received** : 11 Aug 2023
Lab Number : 02575375 **Diagnosed** : 14 Aug 2023
Unique Number : 5620426 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: KV100, VI)

Domtar Inc.
 Box 3001, 1 Duke Street
 Dryden, ON
 CA P8N 2Z7
 Contact: Yvon St. Laurent
 yvon.stlaurent@domtar.com
 T: (807)223-9838
 F: (807)223-9176

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.